

**ARTICLE 11 OF CHAPTER 130A  
OF THE GENERAL STATUTES OF NORTH CAROLINA**

**WASTEWATER SYSTEMS.**

**§ 130A-333. Purpose.**

The General Assembly finds and declares that continued installation, at a rapidly and constantly accelerating rate, of septic tank systems and other types of wastewater systems in a faulty or improper manner and in areas where unsuitable soil and population density adversely affect the efficiency and functioning of these systems, has a detrimental effect on the public health and environment through contamination of land, groundwater and surface waters. Recognizing, however, that wastewater can be rendered ecologically safe and the public health protected if methods of wastewater collection, treatment and disposal are properly regulated and recognizing that wastewater collection, treatment and disposal will continue to be necessary to meet the needs of an expanding population, the General Assembly intends to ensure the regulation of wastewater collection, treatment and disposal systems so that these systems may continue to be used, where appropriate, without jeopardizing the public health. (1973, c. 452, s. 3; 1981, c. 949, s. 3; 1983, c. 891, s. 2; 1991 (Reg. Sess., 1992), c. 944, ss. 1, 2.)

**§ 130A-334. Definitions.**

The following definitions shall apply throughout this Article:

- (1) "Accepted wastewater system" has the same meaning as in G.S. 130A-343.
- (1a) "Approved agency for special inspection" means an individual, corporation, company, association, or partnership that is objective, competent, and independent from the contractor who is responsible for the work that is inspected. The agency shall disclose possible conflicts of interest in a manner such that objectivity can be confirmed.
- (1b) "Approved special inspector" means a person who demonstrates competence to the satisfaction of the professional engineer who designed the wastewater system for the inspection of the construction or operation subject to special inspection.
- (1c) "Construction" means any work at the site of placement done for the purpose of preparing a residence, place of business or place of public assembly for initial occupancy, or subsequent additions or modifications which increase sewage flow.
- (1d) "Construction observation" means the visual observation of the construction and installation of the wastewater system for general conformance with the construction documents prepared by the professional engineer who designed the wastewater system. Construction observation that is conducted by the professional engineer who designed the wastewater system does not include or waive the requirement to conduct special inspections.
- (1e) "Conventional wastewater system" has the same meaning as in G.S. 130A-343.
- (1f) "Department" means the Department of Health and Human Services.
- (1g) "Engineered option permit" means an on-site wastewater system that is permitted pursuant to the rules adopted by the Commission in accordance with this Article, meets the criteria established by G.S. 130A-336.1, and is designed by a professional engineer who is licensed under Chapter 89C of the General Statutes who has expertise in the design of on-site wastewater systems.
- (1h) "Ground absorption system" means a system of tanks, treatment units, nitrification fields, and appurtenances for wastewater collection, treatment, and subsurface disposal.
- (2) Repealed by Session Laws 1985, c. 462, s. 18.
- (2a) "Industrial process wastewater" means any water-carried waste resulting from any process of industry, manufacture, trade, or business.
- (2b) "Licensed geologist" means a person who is licensed as a geologist under the provisions of Chapter 89E of the General Statutes.
- (2c) "Licensed soil scientist" has the same meaning as in G.S. 89F-3.
- (3) "Location" means the initial placement for occupancy of a residence, place of business or place of public assembly.
- (3a) "Maintenance" means normal or routine maintenance including replacement of broken pipes, cleaning, or adjustment to an existing wastewater system.
- (4), (5) Repealed by Session Laws 1985, c. 462, s. 18.
- (6) "Place of business" means a store, warehouse, manufacturing establishment, place of amusement or recreation, service station, office building or any other place where people work.

- (7) "Place of public assembly" means a fairground, auditorium, stadium, church, campground, theater or any other place where people assemble.
- (7a) "Plat" means a property survey prepared by a registered land surveyor, drawn to a scale of one inch equals no more than 60 feet, that includes: the specific location of the proposed facility and appurtenances, the site for the proposed wastewater system, and the location of water supplies and surface waters. "Plat" also means, for subdivision lots approved by the local planning authority if a local planning authority exists at the time of application for a permit under this Article, a copy of the subdivision plat that has been recorded with the county register of deeds and is accompanied by a site plan that is drawn to scale.
- (7b) "Pretreatment" means any biological, chemical, or physical process or system for improving wastewater quality and reducing wastewater constituents prior to final treatment and disposal in a subsurface wastewater system and includes, but is not limited to aeration, clarification, digestion, disinfection, filtration, separation, and settling.
- (7c) "Professional engineer" has the same meaning as in G.S. 89C-3.
- (8) "Public or community wastewater system" means a single system of wastewater collection, treatment and disposal owned and operated by a sanitary district, a metropolitan sewage district, a water and sewer authority, a county or municipality or a public utility.
- (9) "Relocation" means the displacement of a residence or place of business from one site to another.
- (9a) "Repair" means the extension, alteration, replacement, or relocation of existing components of a wastewater system.
- (10) "Residence" means a private home, dwelling unit in a multiple family structure, hotel, motel, summer camp, labor work camp, manufactured home, institution or any other place where people reside.
- (10a) "Secretary" means the Secretary of Health and Human Services.
- (11) Repealed by Session Laws 1992, c. 944, s. 3.
- (12) "Septic tank system" means a subsurface wastewater system consisting of a settling tank and a subsurface disposal field.
- (13) "Sewage" means the liquid and solid human body waste and liquid waste generated by water-using fixtures and appliances, including those associated with foodhandling. The term does not include industrial process wastewater or sewage that is combined with industrial process wastewater.
- (13a) "Site plan" means a drawing not necessarily drawn to scale that shows the existing and proposed property lines with dimensions, the location of the facility and appurtenances, the site for the proposed wastewater system, and the location of water supplies and surface waters.
- (13b) "Special inspection" means a required inspection of the materials, installation, fabrication, erection, or placement of components and systems that require special expertise to ensure compliance with referenced standards and the construction documents prepared by the professional engineer.
- (14) "Wastewater" means any sewage or industrial process wastewater discharged, transmitted, or collected from a residence, place of business, place of public assembly, or other places into a wastewater system.
- (15) "Wastewater system" means a system of wastewater collection, treatment, and disposal in single or multiple components, including a ground absorption system, privy, septic tank system, public or community wastewater system, wastewater reuse or recycle system, mechanical or biological wastewater treatment system, any other similar system, and any chemical toilet used only for human waste. A wastewater system located on multiple adjoining lots or tracts of land under common ownership or control shall be considered a single system for purposes of permitting under this Article. (1973, c. 452, s. 4; 1981, c. 949, s. 3; 1983, c. 891, s. 2; 1985, c. 462, s. 18; c. 487, s. 9; 1987, c. 435; 1991, c. 256, s. 1; 1991 (Reg. Sess., 1992), c. 944, s. 3; c. 1028, s. 4; 1995, c. 285, s. 1; 1995 (Reg. Sess., 1996), c. 585, s. 1; 1996, 2nd Ex. Sess., c. 18, ss. 27.31(a), (b); 1997-443, s. 11A.82; 2011-145, s. 13.3(bbb); 2014-120, s. 40(a); 2015-241, s. 14.30(v); 2015-286, s. 4.14(a).)

**§ 130A-335. Wastewater collection, treatment and disposal; rules.**

(a) A person owning or controlling a residence, place of business or a place of public assembly shall provide an approved wastewater system. Except as may be allowed under another provision of law, all wastewater from

water-using fixtures and appliances connected to a water supply source shall discharge to the approved wastewater system. A wastewater system may include components for collection, treatment and disposal of wastewater.

(a1) Any proposed site for a residence, place of business, or a place of public assembly located in an area that is not served by an approved wastewater system for which a new wastewater system is proposed or repair is necessary for compliance may be evaluated for soil conditions and site features by a licensed soil scientist or licensed geologist. For purposes of this subsection, "site features" include topography and landscape position; soil characteristics (morphology); soil wetness; soil depth; restrictive horizons; available space; and other applicable factors that involve accepted public health principles.

(b) All wastewater systems shall either (i) be regulated by the Department under rules adopted by the Commission or (ii) conform with the engineered option permit criteria set forth in G.S. 130A-336.1 and under rules adopted by the Commission except for the following wastewater systems that shall be regulated by the Department under rules adopted by the Environmental Management Commission:

- (1) Wastewater collection, treatment, and disposal systems designed to discharge effluent to the land surface or surface waters.
- (2) Wastewater systems designed for groundwater remediation, groundwater injection, or landfill leachate collection and disposal.
- (3) Wastewater systems designed for the complete recycle or reuse of industrial process wastewater.
- (4) Gray water systems as defined in G.S. 143-350.

(c) A wastewater system subject to approval under rules of the Commission shall be reviewed and approved under rules of a local board of health in the following circumstances:

- (1) The local board of health, on its own motion, has requested the Department to review its proposed rules concerning wastewater systems; and
- (2) The local board of health has adopted by reference the wastewater system rules adopted by the Commission, with any more stringent modifications or additions deemed necessary by the local board of health to protect the public health; and
- (3) The Department has found that the rules of the local board of health concerning wastewater collection, treatment and disposal systems are at least as stringent as rules adopted by the Commission and are sufficient and necessary to safeguard the public health.

(c1) The rules adopted by the Commission for wastewater systems approved under the engineered option permit criteria pursuant to G.S. 130A-336.1 shall be, at a minimum, as stringent as the rules for wastewater systems established by the Commission.

(d) The Department may, upon its own motion, upon the request of a local board of health or upon the request of a citizen of an affected county, review its findings under subsection (c) of this section.

The Department shall review its findings under subsection (c) of this section upon modification by the Commission of the rules applicable to wastewater systems. The Department may deny, suspend, or revoke the approval of local board of health wastewater system rules upon a finding that the local wastewater rules are not as stringent as rules adopted by the Commission, are not sufficient and necessary to safeguard the public health, or are not being enforced. Suspension and revocation of approval shall be in accordance with G.S. 130A-23.

(d1) The Department or owner of a wastewater system may file a written complaint with the North Carolina Board of Examiners for Engineers and Surveyors in accordance with rules and procedures adopted by the Board pursuant to Chapter 89C of the General Statutes citing failure of a professional engineer to adhere to the rules adopted by the Commission pursuant to this Article. The Department or owner of a wastewater system may file a written complaint with the North Carolina Board of Licensed Soil Scientists in accordance with rules and procedures adopted by the Board pursuant to Chapter 89F of the General Statutes citing failure of a licensed soil scientist to adhere to the rules adopted by the Commission pursuant to this Article. The Department or owner of a wastewater system may file a written complaint with the North Carolina Board for Licensing of Geologists in accordance with rules and procedures adopted by the Board pursuant to Chapter 89E of the General Statutes citing failure of a licensed geologist to adhere to the rules adopted by the Commission pursuant to this Article. The Department or owner of a wastewater system may file a written complaint with the North Carolina On-Site Wastewater Contractors and Inspectors Certification Board in accordance with rules and procedures adopted by the Board pursuant to Article 5 of Chapter 90A of the General Statutes citing failure of a contractor to adhere to the rules adopted by the Commission pursuant to this Article.

(e) The rules of the Commission and the rules of the local board of health shall address at least the following: Wastewater characteristics; Design unit; Design capacity; Design volume; Criteria for the design, installation, operation, maintenance and performance of wastewater collection, treatment and disposal systems; Soil morphology and drainage; Topography and landscape position; Depth to seasonally high water table, rock and water impeding formations; Proximity to water supply wells, shellfish waters, estuaries, marshes, wetlands, areas subject

to frequent flooding, streams, lakes, swamps and other bodies of surface or groundwaters; Density of wastewater collection, treatment and disposal systems in a geographical area; Requirements for issuance, suspension and revocation of permits; and Other factors which affect the effective operation and performance of wastewater collection, treatment and disposal systems. The rules regarding required design capacity and required design volume for wastewater systems shall provide that exceptions may be granted upon a showing that a system is adequate to meet actual daily water consumption.

(f) The rules of the Commission and the rules of the local board of health shall classify systems of wastewater collection, treatment and disposal according to size, type of treatment and any other appropriate factors. The rules shall provide construction requirements, including pretreatment and system control requirements, standards for operation, maintenance, monitoring, reporting, and ownership requirements for each classification of systems of wastewater collection, treatment and disposal in order to prevent, as far as reasonably possible, any contamination of the land, groundwater and surface waters. The Department and local health departments may impose conditions on the issuance of permits and may revoke the permits for failure of the system to satisfy the conditions, the rules, or this Article. Permits other than improvement permits shall be valid for a period prescribed by rule. Improvement permits shall be valid upon a showing satisfactory to the Department or the local health department that the site and soil conditions are unaltered, that the facility, design wastewater flow, and wastewater characteristics are not increased, and that a wastewater system can be installed that meets the permitting requirements in effect on the date the improvement permit was issued. Improvement permits for which a plat is provided shall be valid without expiration. Improvement permits for which a site plan is provided shall be valid for five years. The period of time for which the permit is valid and a statement that the permit is subject to revocation if the site plan or plat, whichever is applicable, or the intended use changes shall be displayed prominently on both the application form for the permit and the permit.

(f1) A preconstruction conference with the owner or developer, or an agent of the owner or developer, and a representative of the local health department shall be required for any authorization for wastewater system construction issued with an improvement permit under G.S. 130A-336 when the authorization is greater than five years old. Following the conference, the local health department shall advise the owner or developer of any rule changes for wastewater system construction incorporating current technology that can reasonably be expected to improve the performance of the system. The local health department shall issue a revised authorization for wastewater system construction incorporating the rule changes upon the written request of the owner or developer.

(f2) For each septic tank system that is designed to treat 3,000 gallons per day or less of sewage, rules adopted pursuant to subsection (f) of this section shall require the use of an effluent filter to reduce the total suspended solids entering the drainfield and the use of an access device for each compartment of the septic tank to provide access to the compartment in order to facilitate maintenance of the septic tank. The Commission shall not adopt specifications for the effluent filter and access device that exceed the requirements of G.S. 130A-335.1. Neither this section nor G.S. 130A-335.1 shall be construed to prohibit the use of an effluent filter or access device that exceeds the requirements of G.S. 130A-335.1. The Department shall approve effluent filters that meet the requirements of this section, G.S. 130A-335.1, and rules adopted by the Commission.

(g) Prior to denial of an improvement permit, the local health department shall advise the applicant of possible site modifications or alternative systems, and shall provide a brief description of those systems. When an improvement permit is denied, the local health department shall issue the site evaluation in writing stating the reasons for the unsuitable classification. The evaluation shall also inform the applicant of the right to an informal review by the Department, the right to appeal under G.S. 130A-24, and to have the appeal held in the county in which the site for which the improvement permit was requested is located.

(h) Except as provided in this subsection, a chemical or portable toilet may be placed at any location where the chemical or portable toilet can be operated and maintained under sanitary conditions. A chemical or portable toilet shall not be used as a replacement or substitute for a water closet or urinal where a water closet or urinal connected to a permanent wastewater treatment system is required by the North Carolina State Building Code, except that a chemical or portable toilet may be used to supplement a water closet or urinal during periods of peak use. A chemical or portable toilet shall not be used as an alternative to the repair of a water closet, urinal, or wastewater treatment system. It shall be unlawful to discharge sewage or other waste from a chemical or portable toilet used for human waste except into a wastewater system that has been approved by the Department under rules adopted by the Commission or by the Environmental Management Commission or at a site that is permitted by the Department under G.S. 130A-291.1. (1957, c. 1357, s. 1; 1973, c. 471, s. 1; c. 476, s. 128; c. 860; 1977, c. 857, s. 1; 1979, c. 788, s. 2; 1981, c. 949, s. 3; c. 1127, s. 47; 1983, c. 891, s. 2; 1987, c. 267, ss. 1, 2; 1989, c. 727, s. 147; c. 764, ss. 6, 7; 1989 (Reg. Sess., 1990), c. 1075, s. 2; 1991 (Reg. Sess., 1992), c. 944, s. 4; 1993, c. 173, s. 5; 1995, c. 285, s. 1; 1995 (Reg. Sess., 1996), c. 585, s. 2; 1996, 2nd Ex. Sess., c. 18, s. 27.31(c); 1998-126, s. 1; 1998-217, s. 46(a); 2008-143, s. 13; 2011-394, s. 12(c); 2014-115, s. 10.1; 2014-120, s. 40(b); 2015-286, s. 4.14(b).)

**§ 130A-335.1. Effluent filters and access devices for certain septic tank systems.**

(a) The person who manufactures, installs, repairs, or pumps any septic tank to be installed in this State as a part of a septic tank system that is designed to treat 3,000 gallons per day or less of sewage shall provide an effluent filter approved by the Department pursuant to the requirements of G.S. 130A-335, this section, and rules adopted by the Commission. Any person who manufactures, installs, repairs, or pumps systems described in this section may purchase and install any approved filters on the systems. The person who installs the effluent filter shall install the effluent filter as a part of the septic tank system in accordance with the specifications provided by the manufacturer of the effluent filter. An effluent filter shall:

- (1) Be made of materials that are capable of withstanding the corrosives to which septic tank systems are normally subject.
- (2) Prevent solid material larger than one-sixteenth of an inch, as measured along the shortest axis of the material, from entering the drainfield.
- (3) Be designed and constructed to allow for routine maintenance.
- (4) Be designed and constructed so as not to require maintenance more frequently than once in any three-year period under normally anticipated use.

(b) The access device required by G.S. 130A-335(f) shall provide access to each compartment of a septic tank for inspection and maintenance either by means of an opening in the top of the septic tank or by a riser assembly and shall include an appropriate cover. The access device shall:

- (1) Be of sufficient size to facilitate inspection and service.
- (2) Be designed and constructed to equal or exceed the minimum loading specifications applicable to the septic tank.
- (3) Prevent water entry.
- (4) Come to within six inches of the finished grade.
- (5) Be visibly marked so that the access device can be readily located. (1998-126, s. 2; 2006-255, s. 4; 2006-264, s. 63(a).)

**§ 130A-336. Improvement permit and authorization for wastewater system construction required.**

(a) Any proposed site for a residence, place of business, or place of public assembly in an area not served by an approved wastewater system shall be evaluated by either (i) the local health department in accordance with rules adopted pursuant to this Article or (ii) by a professional engineer, licensed soil scientist, or licensed geologist acting within the engineer's, soil scientist's, or geologist's scope of work, as applicable, and pursuant to the conditions of the engineered option permit in G.S. 130A-336.1. An improvement permit issued by a local health department shall include:

- (1) For permits that are valid without expiration, a plat, or, for permits that are valid for five years, a site plan.
- (2) A description of the facility the proposed site is to serve.
- (3) The proposed wastewater system and its location.
- (4) The design wastewater flow and characteristics.
- (5) The conditions for any site modifications.
- (6) Any other information required by the rules of the Commission.

Neither the improvement permit nor the authorization for wastewater system construction shall be affected by change of ownership of the site for the wastewater system provided both the site for the wastewater system and the facility the system serves are unchanged and remain under the ownership or control of the person owning the facility. No person shall commence or assist in the construction, location, or relocation of a residence, place of business, or place of public assembly in an area not served by an approved wastewater system unless an improvement permit and an authorization for wastewater system construction are obtained from the local health department unless that person is acting in accordance with the conditions and criteria of an engineered option permit pursuant to G.S. 130A-336.1. This requirement shall not apply to a manufactured residence exhibited for sale or stored for later sale and intended to be located at another site after sale.

(b) The local health department shall issue an authorization for wastewater system construction authorizing work to proceed and the installation or repair of a wastewater system when it has determined after a field investigation that the system can be installed and operated in compliance with this Article and rules adopted pursuant to this Article. This authorization for wastewater system construction shall be valid for a period equal to the period of validity of the improvement permit and may be issued at the same time the improvement permit is issued. No person shall commence or assist in the installation, construction, or repair of a wastewater system unless an improvement permit and an authorization for wastewater system construction have been obtained from the Department or the local health department unless that person is acting in accordance with the conditions and criteria of an engineered option permit pursuant to G.S. 130A-336.1. No improvement permit or authorization for

wastewater system construction shall be required for maintenance of a wastewater system. The Department and the local health department may impose conditions on the issuance of an improvement permit and an authorization for wastewater system construction.

(c) Unless the Commission otherwise provides by rule, plans, and specifications for all wastewater systems designed for the collection, treatment, and disposal of industrial process wastewater shall be reviewed and approved by the Department prior to the issuance of an authorization for wastewater system construction by the local health department.

(d) If a local health department repeatedly fails to issue or deny improvement permits for conventional or accepted septic tank systems within 60 days, or within 90 days for provisional or innovative systems, after receiving completed applications for the permits, then the Department of Health and Human Services may withhold public health funding from that local health department. (1973, c. 452, s. 5; c. 476, s. 128; 1981, c. 949, s. 3; 1983, c. 891, s. 2; 1985, c. 273; 1991, c. 256, s. 2; 1991 (Reg. Sess., 1992), c. 944, s. 5; 1995, c. 285, s. 1; 1995 (Reg. Sess., 1996), c. 585, s. 3; 1996, 2nd Ex. Sess., c. 18, s. 27.31(d)-(f); 1997-443, ss. 11A.83, 11A.119(a); 2014-120, s. 40(c); 2015-241, s. 14.30(u); 2015-286, s. 4.14(g).)

### **§ 130A-336.1. Alternative process for wastewater system approvals.**

(a) **Engineered Option Permit Authorized.** - A professional engineer licensed under Chapter 89C of the General Statutes may, at the direction of the owner of a proposed wastewater system who wishes to utilize the engineered option permit, prepare signed and sealed drawings, specifications, plans, and reports for the design, construction, operation, and maintenance of the wastewater system in accordance with this section and rules adopted thereunder.

(b) **Notice of Intent to Construct.** - Prior to commencing or assisting in the construction, siting, or relocation of a wastewater system, the owner of a proposed wastewater system who wishes to utilize the engineered option permit, or a professional engineer authorized as the legal representative of the owner, shall submit to the local health department with jurisdiction over the location of the proposed wastewater system a notice of intent to construct a wastewater system utilizing the engineered permit option. The Department shall develop a common form for use as the notice of intent to construct that includes all of the following:

- (1) The owner's name, address, e-mail address, and telephone number.
- (2) The professional engineer's name, license number, address, e-mail address, and telephone number.
- (3) For the professional engineer, the licensed soil scientist, the licensed geologist, and any on-site wastewater contractors, proof of errors and omissions insurance coverage or other appropriate liability insurance.
- (4) A description of the facility the proposed site is to serve and any factors that would affect the wastewater load.
- (5) The type of proposed wastewater system and its location.
- (6) The design wastewater flow and characteristics.
- (7) Any proposed landscape, site, drainage, or soil modifications.
- (8) A soil evaluation that is conducted and signed and sealed by a either a licensed soil scientist or licensed geologist.
- (9) A plat, as defined in G.S. 130A-334(7a).

(c) **Completeness Review for Notice of Intent to Construct.** - The local health department shall determine whether a notice of intent to construct, as required pursuant subsection (b) of this section, is complete within 15 business days after the local health department receives the notice of intent to construct. A determination of completeness means that the notice of intent to construct includes all of the required components. If the local health department determines that the notice of intent to construct is incomplete, the department shall notify the owner or the professional engineer of the components needed to complete the notice. The owner or professional engineer may submit additional information to the department to cure the deficiencies in the notice. The local health department shall make a final determination as to whether the notice of intent to construct is complete within 10 business days after the department receives the additional information from the owner or professional engineer. If the department fails to act within any time period set out in this subsection, the owner or professional engineer may treat the failure to act as a determination of completeness.

(d) **Submission of Notice of Intent to Construct to Department for Certain Systems.** - Prior to commencing in the construction, siting, or relocation of a wastewater system designed (i) for the collection, treatment, and disposal of industrial process wastewater or (ii) to treat greater than 3,000 gallons per day, the owner of a proposed wastewater system who wishes to utilize the engineered option permit, or a professional engineer authorized as the legal representative of the owner, shall provide to the Department a duplicate copy of the notice of intent to construct submitted to the local health department required pursuant to subsection (b) of this section.

- (e) Site Design, Construction, and Activities.
- (1) The professional engineer designing the proposed wastewater system shall use recognized principles and practices of engineering and applicable rules of the Commission in the calculations and design of the wastewater system. The investigations and findings of the professional engineer shall include, at a minimum, the information required in rules adopted by the Commission pursuant to G.S. 130A-335(e). The professional engineer may, at the engineer's discretion, employ pretreatment technologies not yet approved in this State.
  - (2) Notwithstanding G.S. 130A-335(a1), the owner of the proposed wastewater system shall employ either a licensed soil scientist or a geologist, licensed pursuant to Chapter 89E of the General Statutes and who has applicable professional experience, to evaluate soil conditions and site features.
  - (3) The professional engineer designing the proposed wastewater system:
    - a. Shall be responsible for the engineer's scope of work, including all aspects of the design and any drawings, specifications, plans, or reports that are signed and sealed by the professional engineer.
    - b. Shall prepare a signed and sealed statement of special inspections that includes the following items:
      1. The materials, systems, components, and work subject to special inspection or testing.
      2. The type and extent of each special inspection and each test.
      3. The frequency of each type of special inspection. For purposes of this sub-sub-subdivision, frequency of special inspections shall be required on either a continuous or periodic basis. Continuous special inspections mean the full-time observation of work requiring special inspection by an approved special inspector who is present in the area where the work is performed. Periodic special inspections mean the part-time or intermittent observation of work requiring a special inspection by an approved special inspector who is present in the area where the work is or has been performed and at the completion of the work.
    - c. May assist the owner of the proposed wastewater system with the selection of an on-site wastewater system contractor certified pursuant to Article 5 of Chapter 90A of the General Statutes.
  - (4) An on-site wastewater system contractor, licensed pursuant to Article 5 of Chapter 90A of the General Statutes, who is employed by the owner of the wastewater system, shall:
    - a. Be responsible for all aspects of the construction and installation of the wastewater system or components of the wastewater system, including adherence to the design, specifications, and any special inspections that are prepared, signed, and sealed by the professional engineer in accordance with all the applicable provisions of this section.
    - b. Submit a signed and dated statement of responsibility to the owner of the wastewater system, prior to the commencement of work, that contains acknowledgement and awareness of the requirements in the professional engineer's statement of special inspections.
  - (5) Where the professional engineer's designs, plans, and specifications call for the installation of a conventional wastewater system, such designs, plans, and specifications shall allow for the installation of an accepted system in lieu of a conventional system in accordance with the accepted system approval.
  - (6) In addition to the requirements of this section, the owner, the professional engineer designing the proposed wastewater system, and any on-site wastewater system contractors employed to construct or install the wastewater system shall comply with applicable federal, State, and local laws, regulations, rules, and ordinances.
- (f) No Public Liability. - The Department, the Department's authorized agents, or local health departments shall have no liability for wastewater systems designed, constructed, and installed pursuant to a engineered option permit.
- (g) Inspections, Construction Observations, and Reports. -
- (1) Site visits. - The local health department may, at any time, conduct a site visit of the wastewater system.

- (2) Construction observations. - The professional engineer who designed the wastewater system shall make periodic visits to the site, at intervals appropriate to the stage of construction, to observe the progress and quality of the construction and to determine, generally, if the construction is proceeding in accordance with the engineer's plans and specifications.
- (3) Special inspections. - The owner of the proposed wastewater system shall employ one or more approved special inspectors to conduct special inspections during the construction of the wastewater system. The professional engineer who designed the wastewater system, or the engineer's personnel, may function as an approved agency to conduct special inspections required by this subdivision. The professional engineer's personnel shall only operate as an approved agency for special inspections if the personnel can demonstrate competence and relevant experience or training. For purposes of this subdivision, experience or training shall be considered relevant when the documented experience or training is related in complexity to the same type of special inspection activities for projects of similar complexity and material qualities.
- (4) Inspection reports. - Approved special inspectors shall maintain and furnish all inspection records to the professional engineer who designed the wastewater system. The records shall indicate whether the work inspected was completed in conformance with the engineer's design and specifications. Any discrepancies identified between the completed work and the engineer's design shall be brought to the immediate attention of the on-site wastewater system contractor for correction. If discrepancies are not corrected, they shall be brought to the attention of the professional engineer who designed the wastewater system prior to completion of work. A final inspection report documenting the required special inspections and the correction of any identified discrepancies shall be provided to the professional engineer and the owner of the wastewater system for review at the post-construction conference required pursuant to subsection (j) of this section.

(h) Local Authority. - This section shall not relieve the owner or operator of a wastewater system from complying with any and all modifications or additions to rules adopted by a local health department to protect public health pursuant to G.S. 130A-335(c) that are required at the time the owner or operator submits the notice of intent to construct pursuant to G.S. 130A-336.1(b). The local health department shall notify the owner or operator of the wastewater system of any issues of compliance related to such modifications or additions.

(i) Operations and Management. -

- (1) The professional engineer designing the wastewater system shall establish a written operations and management program based on the size and complexity of the wastewater system and shall provide the program to the owner.
- (2) The owner shall enter into a contract with a water pollution control system operator certified pursuant to Part 1 of Article 3 of Chapter 90A of the General Statutes and who is selected from the list of certified operators maintained by the Division of Water Resources in the Department of Environment and Natural Resources for operation and maintenance of the wastewater system in accordance with rules adopted by the Commission.
- (3) The owner of the wastewater system shall be responsible for the continued adherence to the operations and management program established by the professional engineer pursuant to subdivision (1) of this subsection.

(j) Post-Construction Conference. - The professional engineer designing the wastewater system shall hold a post-construction conference with the owner of the wastewater system; the licensed soil scientist or licensed geologist who performed the soils evaluation for the wastewater system; the on-site wastewater system contractor, certified pursuant to Article 5 of Chapter 90A of the General Statutes, who installed the wastewater system; the certified operator of the wastewater system, if any; and representatives from the local health department and, as applicable, the Department. The post-construction conference shall include start-up of the wastewater system and any required verification of system design or system components.

(k) Required Documentation. -

- (1) At the completion of the post-construction conference conducted pursuant to subsection (j) of this section, the professional engineer who designed the wastewater system shall deliver to the owner signed, sealed, and dated copies of the engineer's report, which, for purposes of this subsection, shall include the following:
  - a. The evaluation of soil conditions and site features as prepared by either the licensed soil scientist or licensed geologist.
  - b. The drawings, specifications, plans, and reports of the wastewater system, including the statement of special inspections required pursuant to G.S. 130A-336.1(e)(3); the

on-site wastewater system contractor's signed statement of responsibility required pursuant to G.S. 130A-336.1(e)(4); records of all special inspections; and the final inspection report documenting the correction of any identified discrepancies required pursuant to subsection (g) of this section.

- c. The operator's management program manual that includes a copy of the contract with the certified water pollution control system operator required pursuant to subsection (i) of this section.
  - d. Any reports and findings related to the design and installation of the wastewater system.
- (2) Upon reviewing the professional engineer's report, the owner of the wastewater system shall sign and notarize the report as having been received.
- (l) Reporting Requirements. -
- (1) The owner of the wastewater system shall submit the following to the local health department:
    - a. A copy of the professional engineer's report required pursuant to G.S. 130A-336.1(k)(1).
    - b. A copy of the operations and management program.
    - c. The fee required pursuant to subsection (n) of this section.
    - d. A notarized letter that documents the owner's acceptance of the system from the professional engineer.
  - (2) The owner of any wastewater system that is subject to subsection (d) of this section shall deliver to the Department copies of the engineer's report, as described G.S. 130A-336.1(k)(1).
- (m) Authorization to Operate. - Within 15 business days of receipt of the documents and fees required pursuant to G.S. 130A-336.1(l)(1), the local health department shall issue the owner a letter of confirmation that states the documents and information contained therein have been received and that the wastewater system may operate in accordance with rules adopted by the Commission.
- (n) Fees. - The local health department may assess a fee for the engineered option permit of up to thirty percent (30%) of the cumulative total of the fees the department has established to obtain an improvement permit, an authorization to construct, and an operations permit for wastewater systems under its jurisdiction. The fee shall only be used by the department in support of its work pursuant to this section to conduct site inspections; support the department's staff participation at post-construction conference meetings; and archive the engineered permit with the county register of deeds or other recordation of the wastewater system as required.
- (o) Change in System Ownership. - A wastewater system authorized pursuant to this section shall not be affected by change in ownership of the site for the wastewater system, provided both the site for the wastewater system and the facility the system serves are unchanged and remain under the ownership or control of the person owning the facility.
- (p) Remedies. - Notwithstanding any other provision of this section or any other provision of law, owners; operators; professional engineers who utilize the engineered option permit, who prepare drawings, specifications, plans, and reports; licensed soil scientists; licensed geologists; and on-site wastewater system contractors employed for the construction or installation of the wastewater system shall be subject to the provisions and remedies provided to the Department and local health departments pursuant to Article 1 of this Chapter.
- (q) Rule Making. - The Commission shall adopt rules to implement the provisions of this section.
- (r) Reports. - The Department shall report to the Environmental Review Commission and the Joint Legislative Oversight Committee on Health and Human Services on or before January 1, 2017, and annually thereafter, on the implementation and effectiveness of this section. For the report due on or before January 1, 2017, the Department shall specifically study (i) whether the engineered option permit resulted in a reduction in the length of time improvement permits or authorizations to construct are pending; (ii) whether the engineered option permit resulted in increased system failures or other adverse impacts; (iii) if the engineered option permit resulted in new or increased environmental or public health impacts; (iv) an amount of errors and omissions insurance or other liability sufficient for covering professional engineers, licensed soil scientists, licensed geologists, and contractors who employ the engineered option permit; and (v) the fees charged by local health departments to administer the engineered option permit pursuant to subsection (n) of this section. The Department may include recommendations, including any legislative proposals, in its reports to the Commission and Committee. (2015-286, s. 4.14(c).)

**§ 130A-337. Inspection; operation permit required.**

- (a) No system of wastewater collection, treatment and disposal shall be covered or placed into use by any person until an inspection by the local health department has determined that the system has been installed or repaired in accordance with any conditions of the improvement permit, the rules, and this Article.

(b) Upon determining that the system is properly installed or repaired and that the system is capable of being operated in accordance with the conditions of the improvement permit, the rules, this Article and any conditions to be imposed in the operation permit, as applicable, the local health department shall issue an operation permit authorizing the residence, place of business or place of public assembly to be occupied and for the system to be placed into use or reuse.

(c) Upon determination that an existing wastewater system has a valid operation permit and is operating properly in a manufactured home park, the local health department shall issue authorization in writing for a manufactured home to be connected to the existing system and to be occupied. Notwithstanding G.S. 130A-336, an improvement permit is not required for the connection of a manufactured home to an existing system with a valid operation permit in a manufactured home park.

(d) No person shall occupy a residence, place of business or place of public assembly, or place a wastewater system into use or reuse for a residence, place of business or place of public assembly until an operation permit has been issued or authorization has been obtained pursuant to G.S. 130A-337(c). (1973, c. 452, s. 6; 1981, c. 949, s. 3; 1983, c. 891, s. 2; 1985, c. 487, s. 9; 1991 (Reg. Sess., 1992), c. 944, s. 6; 1995, c. 285, s. 1.)

**§ 130A-338. Authorization for wastewater system construction required before other permits to be issued.**

Where construction, location or relocation is proposed to be done upon a residence, place of business or place of public assembly, no permit required for electrical, plumbing, heating, air conditioning or other construction, location or relocation activity under any provision of general or special law shall be issued until an authorization for wastewater system construction has been issued under G.S. 130A-336, or authorization has been obtained under G.S. 130A-337(c), or a decision on the completeness of the notice of intent to construct is made by the local health department pursuant to G.S. 130A-336.1(c). (1973, c. 452, s. 7; 1981, c. 949, s. 3; 1983, c. 891, s. 2; 1995, c. 285, s. 1; 2015-286, s. 4.14(d).)

**§ 130A-339. Limitation on electrical service.**

No person shall allow permanent electrical service to a residence, place of business or place of public assembly upon construction, location or relocation until the official electrical inspector with jurisdiction as provided in G.S. 143-143.2 certifies to the electrical supplier that the required improvement permit authorization for wastewater system construction and an operation permit or authorization under G.S. 130A-337(c) or the letter of confirmation authorizing wastewater system operation under G.S. 130A-336.1(m) has been obtained. Temporary electrical service necessary for constructing a residence, place of business or place of public assembly can be provided upon compliance with G.S. 130A-338. (1973, c. 452, s. 8; 1981, c. 949, s. 3; 1983, c. 891, s. 2; 1995, c. 285, s. 1; 2015-286, s. 4.14(e).)

**§ 130A-340. Review procedures and appeals.**

The Department, upon request by an applicant for an improvement permit, shall provide a technical review of any scientific data and system design submitted by the applicant. The data and system design shall be evaluated by professional peers of those who prepared the data and system design. The results of the technical review shall be available prior to a decision by the local health department and shall not affect an applicant's right to a contested hearing under Chapter 150B of the General Statutes. (1989, c. 764, s. 5.)

**§ 130A-341. Consideration of a site with existing fill.**

Upon application to the local health department, a site that has existing fill, including one on which fill material was placed prior to July 1, 1977, and that has sand or loamy sand for a depth of at least 36 inches below the existing ground surface, shall be evaluated for an on-site wastewater system. The Commission shall adopt rules to implement this section. (1989, c. 764, s. 8; 1991 (Reg. Sess., 1992), c. 944, s. 7.)

**§ 130A-342. Residential wastewater treatment systems.**

(a) Individual residential wastewater treatment systems that are approved and listed in accordance with the standards adopted by the National Sanitation Foundation, Inc. for Class I residential wastewater treatment systems, as set out in Standard 40 of the National Sanitation Foundation, Inc., (as approved 13 January 2001) as amended, shall be permitted under rules adopted by the Commission. The Commission may establish standards in addition to those set by the National Sanitation Foundation, Inc.

(b) A permitted system with a design flow of less than 1,500 gallons per day shall be operated by a person who is a Subsurface Water Pollution Control System Operator as certified by the Water Pollution Control System Operators Certification Commission and authorized by the manufacturer of the individual residential wastewater treatment system. The Commission may, in addition to the requirement for a certified Subsurface Water Pollution

Control System Operator, establish additional standards for wastewater systems with a design flow of 1,500 gallons or greater per day.

(c) Each county, in which one or more residential wastewater treatment systems permitted pursuant to this section are in use, shall document the performance of each system and report the results to the Department annually. (1989, c. 727, s. 223(b); c. 764, s. 9; 1989 (Reg. Sess., 1990), c. 1004, ss. 12, 37; 1991 (Reg. Sess., 1992), c. 944, s. 8; 1995, c. 285, s. 1; 1997-443, ss. 11A.84, 11A.119(a); 2001-505, s. 2.1; 2015-286, s. 4.14(j).)

**§ 130A-343. Approval of on-site subsurface wastewater systems.**

(a) Definitions. - As used in this section:

- (1) "Accepted wastewater dispersal system" means any subsurface wastewater dispersal system, other than a conventional wastewater system, that: (i) has been previously approved as an innovative wastewater dispersal system by the Department; (ii) has been in general use in this State as an innovative wastewater dispersal system for more than five years; and (iii) has been approved by the Commission for general use or use in one or more specific applications. An accepted wastewater dispersal system may be approved for use in applications for which a conventional wastewater system is unsuitable. The Commission may impose any design, operation, maintenance, monitoring, and management requirements on the use of an accepted wastewater dispersal system that it determines to be appropriate.
- (2) Recodified as subdivision (a)(7).
- (3) "Conventional wastewater system", "conventional sewage system", or "conventional septic tank system" means a subsurface wastewater system that consists of a traditional septic or settling tank and a gravity-fed subsurface dispersal field that uses washed natural stone or gravel of approved size and grade and piping to distribute effluent to soil in one or more nitrification trenches and that does not include any other appurtenance.
- (4) Repealed by Session Laws 2015-286, s. 4.15(a), effective October 22, 2015.
- (5) "Innovative wastewater system" means any wastewater system, other than a conventional wastewater system or a provisional wastewater system, or any technology, device, or component of a wastewater system that: (i) has been demonstrated to perform in a manner equal or superior to a conventional wastewater system; (ii) is constructed of materials whose physical and chemical properties provide the strength, durability, and chemical resistance to allow the system to withstand loads and conditions as required by rules adopted by the Commission; and (iii) has been approved by the Department for general use or for one or more specific applications. An innovative wastewater system may be approved for use in applications for which a conventional wastewater system is unsuitable. The Department may impose any design, operation, maintenance, monitoring, and management requirements on the use of an innovative wastewater system that it determines to be appropriate. A wastewater system approved by a nationally recognized certification body and in compliance with the ongoing verification program of such body may submit a sampling protocol for innovative system approval that reduces the data sets required for such approval by fifty percent (50%). Such an application shall include all of the data associated with the nationally recognized certification body's verification of the system's performance.
- (6) "Nationally recognized certification body" means a third-party certification body for wastewater systems or system components that is accredited by an entity widely recognized in the United States such as the American National Standards Institute, the Standards Council of Canada, or the International Accreditation Service, Inc.
- (7) "Provisional wastewater system" means any wastewater system or any technology, device, or component of a wastewater system that, on the basis of (i) research acceptable to the Department or (ii) approval of the wastewater system by a nationally recognized certification body for a period that exceeds one year for research, testing, or trial use under actual field conditions in this State pursuant to a protocol that has been approved by the Department.

(b) Adoption of Rules Governing Approvals. - The Commission shall adopt rules for the approval and permitting of innovative, conventional, provisional, and accepted wastewater systems. The rules shall address the criteria to be considered prior to issuing an approval for a system, requirements for preliminary design plans and specifications that must be submitted, methodology to be used, standards for monitoring and evaluating the system, research evaluation of the system, the plan of work for monitoring system performance and maintenance, and any additional matters the Commission determines are necessary for verification of the performance of a wastewater system or system component.

(c) Procedure for Modifications or Revocations. - The Department may modify, suspend, or revoke the approval of a wastewater system if the Department determines that the approval is based on false, incomplete, or misleading information or if the Department finds that modification, suspension, or revocation is necessary to protect public health, safety, or welfare. The Department shall provide a listing of all approved innovative, provisional, and accepted wastewater systems to the local health departments annually, and notify the local health departments within 30 days of any modification or revocation of an approval of a wastewater system or system component.

(d) Evaluation Protocols. - The Department shall approve one or more nationally recognized protocols for the evaluation of wastewater systems. Any protocol approved by the Department shall specify a minimum number of sites that must be evaluated and the duration of the evaluation period. At the request of a manufacturer of a wastewater system, the Department may approve an alternative protocol for use in the evaluation of the performance of the manufacturer's wastewater system. A protocol for the evaluation of a wastewater system approved by the Department pursuant to this section is a scientific standard within the meaning of G.S. 150B-2(8a)h.

(e) Repealed by Session Laws 2015-286, s. 4.15(a), effective October 22, 2015.

(f) Provisional Systems. - A manufacturer of a wastewater system may apply to the Department to have the system provisionally approved for use in this State. Any wastewater system approved based on its approval by a nationally recognized certification body must be designed and installed in a manner consistent with the system evaluated and approved by the nationally recognized certification body. The manufacturer shall submit a proposal for evaluation of the system to the Department. The proposal shall contain procedures for obtaining specified information necessary to achieve innovative status upon completion of the provisional status. The proposal for evaluation shall include the design of the system, a description of any laboratory or field research or testing that will be used to evaluate the system, a description of the research or testing protocol, and the credentials of the independent laboratory, consultant, or other entity that will be conducting the research or testing on the system. The proposal may include an evaluation of research and testing conducted in other states to the extent that the research and testing involves soil types, climate, hydrology, and other relevant conditions that are comparable to conditions in this State and if the research or testing was conducted pursuant to a protocol acceptable to the Department. The manufacturer shall enter into a contract for an evaluation of the performance of the controlled demonstration wastewater system with an independent laboratory, consultant, or other entity that has expertise in the evaluation of wastewater systems and that is approved by the Department. The manufacturer may install up to 200 provisional wastewater systems on sites that are suitable for a conventional wastewater system and that have a repair area of sufficient size to allow installation of a conventional wastewater system, an approved innovative wastewater system, or an accepted wastewater system if the provisional wastewater system fails to perform properly. If the provisional wastewater system is intended for use on sites that are not suitable for a conventional wastewater system, the Department may approve the installation of the provisional wastewater system if the Department determines that the manufacturer can provide an acceptable alternative method for collection, treatment, and dispersal of the wastewater. The Department shall approve applications for provisional systems based on approval by a nationally recognized certification body within 90 days of receipt of a complete application. A manufacturer that chooses to remove its product from the nationally recognized standard during the provisional approval may continue its application in this State pursuant to requirements and procedures established by the Department.

(g) Innovative Systems. - A manufacturer of a wastewater system for on-site subsurface use may apply for and be considered for innovative system status by the Department in one of the following ways:

- (1) If the wastewater system has been approved as a provisional wastewater system pursuant to subsection (f) of this section, the manufacturer may apply to have the system approved as an innovative wastewater system based on successful completion of the evaluation protocols established pursuant to subsection (d) of this section.
- (2) If the wastewater system has not been evaluated or approved as a provisional wastewater system pursuant to subsection (f) of this section, the manufacturer may apply to the Department to have the system approved as an innovative wastewater system on the basis of comparable research and testing conducted in other states. The manufacturer shall provide the Department with the data and findings of all evaluations of the performance of the system that have been conducted in any state by or on behalf of the manufacturer. The manufacturer shall also provide the Department with a summary of the data and findings of all other evaluations of the performance of the system that are known to the manufacturer.
- (3) If the wastewater system has not been evaluated or approved as a provisional system pursuant to subsection (f) of this section, but has been evaluated under protocol established by a nationally recognized certification body for at least two consecutive years, has been found to perform acceptably based on the criteria of the protocol, and is designed and will be installed in a manner consistent with the system evaluated and approved by the nationally recognized

certification body, the manufacturer may apply to have the system approved as an innovative wastewater system.

Within 30 days of receipt of the initial application, the Department shall either (i) notify the manufacturer of any items necessary to complete the application or (ii) notify the manufacturer that its application is complete. The Department shall publish a notice that the manufacturer has submitted an application under this subsection in the North Carolina Register and may provide additional notice to the public via the Internet or by other means. The Department shall receive public comment on the application for at least 30 days after the date the notice is published in the North Carolina Register. In making a determination under this subsection, the Department shall consider the data, findings, and recommendations submitted by the manufacturer and all public comment. The Department may also consider any other information that the Department determines to be relevant. The Department shall determine: (i) whether the system performs in a manner equal or superior to a conventional wastewater system, in terms of structural integrity, treatment, and hydraulic performance; (ii) whether the system is constructed of materials whose physical and chemical properties provide the strength, durability, and chemical resistance to allow the system to withstand loads and conditions as required by rules adopted by the Commission; (iii) the circumstances in which use of the system is appropriate; and (iv) any conditions and limitations related to the use of the system. The Department shall make the determinations required by this subsection and approve or deny the application within 90 days after the Department receives a complete application from a manufacturer. If the Department fails to act on the application within 90 days of the notice of receipt of the complete application, the manufacturer may treat the application as denied and challenge the denial by filing a contested case as provided in Article 3 of Chapter 150B of the General Statutes. If the Department approves an innovative wastewater system, the Department shall notify the manufacturer of the approval and specify the circumstances in which use of the system is appropriate and any conditions and limitations related to the use of the system.

(g1) Approval of Functionally Equivalent Trench Systems as Innovative Systems. - A manufacturer of a wastewater trench system may petition the Commission to have the wastewater trench system approved as an innovative wastewater system as provided in this subsection.

- (1) The Commission shall approve a wastewater trench system as an innovative wastewater system if it finds that there is clear, convincing, and cogent evidence that the wastewater trench system is functionally equivalent to a wastewater trench system that is approved as an accepted wastewater system. A wastewater trench system shall be considered functionally equivalent to an accepted wastewater trench system if the performance characteristics of the wastewater trench system satisfy all of the following requirements:
  - a. The physical properties and chemical durability of the materials from which the wastewater trench system is constructed are equal to or superior to the physical properties and chemical durability of the materials from which the accepted wastewater trench system is constructed.
  - b. The permeable sidewall area and bottom infiltrative area of the wastewater trench system are equal to or greater than the permeable sidewall area and bottom infiltrative area of the accepted wastewater trench system at a field-installed size.
  - c. The wastewater trench system utilizes a similar method and manner of function for the conveyance and application of effluent as the accepted wastewater trench system.
  - d. The structural integrity of the wastewater trench system is equal to or superior to the structural integrity of the accepted wastewater trench system.
  - e. The wastewater trench system shall provide a field installed system storage volume equal to or greater than the field installed system storage volume of the accepted wastewater trench system.
- (2) As part of its petition, the manufacturer shall provide to the Commission all of the following information:
  - a. Specifications of the wastewater trench system.
  - b. Data necessary to demonstrate that the wastewater trench system is functionally equivalent to a wastewater trench system that is approved as an accepted wastewater system.
  - c. A certified statement from an independent, third-party professional engineer or testing laboratory that, based on verified documentation, the wastewater trench system is functionally equivalent to an accepted wastewater system.
- (3) Approval of a wastewater trench system as an innovative wastewater system shall not be conditioned on the manufacturer of the wastewater trench system having operational systems installed in the State.

- (4) The Commission shall authorize the use of a wastewater trench system as an innovative wastewater system in the same applications as the accepted wastewater trench system.
- (5) The Commission shall not include conditions and limitations in the approval of a wastewater trench system as an innovative wastewater system that are not included in the approval of the accepted wastewater trench system.

(h) **Accepted Wastewater Dispersal Systems.** - A manufacturer of an innovative wastewater dispersal system that has been in general use in this State for a minimum of five years may petition the Commission to have the system designated as an accepted wastewater system as provided in this subsection. The manufacturer shall provide the Commission with the data and findings of all prior evaluations of the performance of the system in this State and other states referenced in the petition, including disclosure of any conditions found to result in unacceptable structural integrity, treatment, or hydraulic performance. In addition, the manufacturer shall provide the Commission with information sufficient to enable the Commission to fully evaluate the performance of the system in this State for at least the five-year period immediately preceding the petition. The Commission shall designate a wastewater system as an accepted wastewater system only if it finds that there is clear, convincing, and cogent evidence (i) to confirm the findings made by the Department at the time the Department approved the system as an innovative wastewater system and (ii) that the system performs in a manner that is equal or superior to a conventional wastewater system under actual field conditions in this State. The Commission shall specify the circumstances in which use of the system is appropriate and any conditions and limitations related to the use of the system.

(i) **Nonproprietary Wastewater Systems.** - The Department may initiate a review of a nonproprietary wastewater system and approve the system for use as a provisional wastewater system or an innovative wastewater system without having received an application from a manufacturer. The Department may recommend that the Commission designate a nonproprietary wastewater system as an accepted wastewater system without having received a petition from a manufacturer.

(j) Repealed by Session Laws 2015-286, s. 4.15(a), effective October 22, 2015.

(j1) **Clarification With Respect to Certain Dispersal Media.** - In considering the application by a manufacturer of a wastewater system utilizing expanded polystyrene synthetic aggregate particles as a septic effluent dispersal medium for approval of the system under this section, neither the Commission nor the Department may condition, delay, or deny the approval based on the particle or bulk density of the expanded polystyrene material. With respect to approvals already issued by the Department or Commission that include conditions or requirements related to the particle or bulk density of expanded polystyrene material, the Commission or Department, as applicable, shall promptly reissue all such approvals with the conditions and requirements relating to the density of expanded polystyrene material permanently deleted while leaving all other terms and conditions of the approval intact.

(k) **Fees.** - The Department shall collect the following fees under this section:

(1) Review of an alternative protocol under subsection (d) of this section	\$1,000.00
(2) Review of an experimental system	\$3,000.00
(3) Review of a controlled demonstration system	\$3,000.00
(4) Review of an innovative system	\$3,000.00
(5) Review of an accepted system	\$3,000.00
(6) Review of a residential wastewater treatment system pursuant to G.S. 130A-342	\$1,500.00
(7) Review of a component of a system	\$100.00
(8) Modification to approved innovative system	\$1,000.00

(l) **On-Site Wastewater System Account.** - The On-Site Wastewater System Account is established as a nonreverting account within the Department. Fees collected pursuant to this section shall be placed in the On-Site Wastewater System Account and shall be applied only to the costs of implementing this section. (1989, c. 764, s. 10; 1991 (Reg. Sess., 1992), c. 944, s. 9; 1995, c. 285, s. 1; 2001-505, s. 2.2; 2011-261, s. 1; 2014-120, s. 28(a); 2015-286, s. 4.15(a).)

**§ 130A-343.1. Transfer of ownership of provisionally approved septic tanks and innovative septic tank systems to joint agency in certain counties; inspection fees in those counties.**

(a) As used in this section, "provisionally approved septic tank or innovative septic tank system" means a septic tank system located in soil that is classified as provisionally suitable or an innovative septic tank system, as those terms are used in Subchapter 18A of Chapter 18 of Title 15A of the North Carolina Administrative Code, G.S. 130A-343, and any applicable local rules or ordinances.

(b) As used in this subsection, "unit of local government" has the same meaning as in G.S. 160A-460. One or more units of local government located in the Counties of Camden, Chowan, Currituck, Gates, Hertford,

Pasquotank, Perquimans, Tyrrell, and Washington may establish a joint agency for the purpose of owning and operating a provisionally approved septic tank or innovative septic tank system as provided in Article 20 of Chapter 160A of the General Statutes. Bertie County may join any joint agency established under this subsection. The owner of any provisionally approved septic tank or innovative septic tank system may, upon acceptance by a joint agency established under this subsection, transfer ownership of any real or personal property or interest therein that is a part of or used in connection with the provisionally approved septic tank or innovative septic tank system to the joint agency. Notwithstanding G.S. 160A-462(a), a joint agency created pursuant to this subsection may hold real property necessary to the undertaking. Any county named in this subsection may accept real or personal property described in this subsection from the owner of the property for transfer to a joint agency established as provided in this subsection.

(c) The Counties of Bertie, Camden, Chowan, Currituck, Gates, Hertford, Pasquotank, Perquimans, Tyrrell, and Washington may adopt an ordinance providing that any fee for the inspection, maintenance, and repair of a provisionally approved septic tank or other innovative septic tank system may be billed as property taxes, may be payable in the same manner as property taxes, and in the case of nonpayment, may be collected in any manner by which property taxes can be collected. If the ordinance states that delinquent fees can be collected in the same manner as delinquent real property taxes, the delinquent fees are a lien on the real property described on the bill that includes the fee. (1999-288, ss. 1-3; 2001-78, ss. 1-3.)

**§ 130A-344: Repealed by Session Laws 1995, c. 285, s. 2.**

**§ 130A-345. Disposal of liquid condensate from residential heating and cooling systems.**

Notwithstanding any other provision of law, every public or community wastewater system, as defined in G.S. 130A-334(8), shall provide for the collection of liquid condensate from residential heating and cooling systems by the public or community wastewater system. (2015-207, s. 6.)

## **ADDITIONAL RELEVANT STATUTES**

### **Part 2 of Article 9 of Chapter 130A of the General Statutes of North Carolina**

#### **§ 130A-291.2. Temporary domestic wastewater holding tanks.**

When a permanent domestic wastewater collection and treatment system is not available at a construction site or a temporary special event, a temporary wastewater holding tank of adequate capacity to prevent overflow may be used under a mobile or modular office to accommodate domestic wastewater from a commode and sink. The wastewater shall be removed often enough to prevent the temporary domestic wastewater holding tank from overflowing. The owner or lessee of a temporary construction trailer shall contract with a registered septage management firm or registered portable toilet sanitation firm for the removal of domestic waste. The wastewater shall be removed from the temporary domestic wastewater holding tank by a septage management firm holding a current permit to operate a septage firm. (2001-505, s. 1.2.)

**Article 5 of Chapter 90A of the General Statutes of North Carolina**  
**Certification of On-Site Wastewater Contractors and Inspectors.**

Article 5.

Certification of On-Site Wastewater Contractors and Inspectors.

**§ 90A-70. Purpose.**

It is the purpose of this Article to protect the environment and public health, safety, and welfare by ensuring the integrity and competence of on-site wastewater contractors and inspectors; to require the examination of on-site wastewater contractors and inspectors and the certification of their competency to supervise or conduct the construction, installation, repair, or inspection of on-site wastewater systems; to establish minimum standards for ethical conduct, responsibility, training, experience, and continuing education for on-site wastewater system contractors and inspectors; and to provide appropriate enforcement procedures for rules adopted by the North Carolina On-Site Wastewater Contractors and Inspectors Certification Board. (2006-82, s. 1.)

**§ 90A-71. Definitions.**

The following definitions apply in this Article:

- (1) "Board" means the North Carolina On-Site Wastewater Contractors and Inspectors Certification Board.
- (2) "Contractor" means a person who constructs, installs, or repairs, or offers to construct, install, or repair an on-site wastewater system in the State.
- (3) "Conventional wastewater system" has the same meaning as in G.S. 130A-343(a)(3).
- (4) "Department" means the Department of Health and Human Services.
- (4a) "Inspection" means an examination of an on-site wastewater system permitted under the provisions of Article 11 of Chapter 130A of the General Statutes that satisfies all of the following criteria:
  - a. Is requested by a lending institution, realtor, prospective homebuyer, or other impacted party as a condition of sale, refinancing, or transfer of title.
  - b. Meets the minimum requirements established by the Board.
- (5) "Inspector" means a person who conducts an inspection in accordance with rules adopted by the Board.
- (6) "On-site wastewater system" means any wastewater system permitted under the provisions of Article 11 of Chapter 130A of the General Statutes that does not discharge to a treatment facility or the surface waters of the State.
- (7) "Person" means all persons, including individuals, firms, partnerships, associations, public or private institutions, municipalities, or political subdivisions, governmental agencies, or private or public corporations organized and existing under the laws of this State or any other state or country.
- (8) "Wastewater treatment facility" means a mechanical or chemical treatment facility serving a site with multiple wastewater sources. (2006-82, s. 1; 2010-31, s. 13.2(e); 2011-145, s. 13.3(l).)

**§ 90A-72. Certification required; applicability.**

(a) Certification Required. - No person shall construct, install, or repair or offer to construct, install, or repair an on-site wastewater system permitted under Article 11 of Chapter 130A of the General Statutes without being certified as a contractor at the required level of certification for the specified system. No person shall conduct an inspection or offer to conduct an inspection of an on-site wastewater system as permitted under Article 11 of Chapter 130A of the General Statutes without being certified in accordance with the provisions of this Article.

(b) Applicability. - This Article does not apply to the following:

- (1) A person who is employed by a certified contractor or inspector in connection with the construction, installation, repair, or inspection of an on-site wastewater system performed under the direct and personal supervision of the certified contractor or inspector in charge.
- (2) A person who constructs, installs, or repairs an on-site wastewater system described as a single septic tank with a gravity-fed gravel trench dispersal media when located on land owned by that person and that is intended solely for use by that person and members of that person's immediate family who reside in the same dwelling.
- (3) A person licensed under Article 1 of Chapter 87 of the General Statutes who constructs or installs an on-site wastewater system ancillary to the building being constructed or who

- provides corrective services and labor for an on-site wastewater system ancillary to the building being constructed.
- (4) A person who is certified by the Water Pollution Control System Operators Certification Commission and contracted to provide necessary operation and maintenance on the permitted on-site wastewater system.
  - (5) A person permitted under Article 21 of Chapter 143 of the General Statutes who is constructing a water pollution control facility necessary to comply with the terms and conditions of a National Pollutant Discharge Elimination System (NPDES) permit.
  - (6) A person licensed under Article 1 of Chapter 87 of the General Statutes as a licensed public utilities contractor who is installing or expanding a wastewater treatment facility, including a collection system, designed by a registered professional engineer.
  - (7) A plumbing contractor licensed under Article 2 of Chapter 87 of the General Statutes, so long as the plumber is not performing plumbing work that includes the installation or repair of a septic tank or similar depository, such as a treatment or pretreatment tank or system, or lines, tanks, or appurtenances downstream from the point where the house or building sewer lines from the plumbing system meet the septic tank or similar depository. This subdivision shall not be construed to require a plumbing contractor to become certified as a contractor pursuant to this section to install or repair a grease trap, interceptor, or separator upstream from a septic tank or similar depository that complies with the requirements of the local health department.
  - (8) A person employed by the Department, a local health department, or a local health district, when conducting a regulatory inspection of an on-site wastewater system for purposes of determining compliance. (2006-82, s. 1; 2010-31, s. 13.2(f); 2015-286, s. 4.14A.)

**§ 90A-73. Creation and membership of the Board.**

- (a) Creation and Appointments. – There is created the North Carolina On-Site Wastewater Contractors and Inspectors Certification Board. The Board shall consist of nine members appointed to three-year terms as follows:
- (1) One member appointed by the Governor who, at the time of appointment, is engaged in the construction, installation, repair, or inspection of on-site wastewater systems, to a term that expires on 1 July of years that precede by one year those years that are evenly divisible by three.
  - (2) One member appointed by the Governor who, at the time of appointment, is a certified water pollution control system operator pursuant to Article 3 of this Chapter, to a term that expires on 1 July of years evenly divisible by three.
  - (3) One member appointed by the Governor who is a registered professional engineer licensed under Chapter 89C of the General Statutes and whose work experience includes the design of on-site wastewater systems to a term that expires on 1 July of years that follow by one year those years that are evenly divisible by three.
  - (4) One member appointed by the General Assembly upon recommendation of the President Pro Tempore of the Senate who, at the time of appointment, is engaged in the construction, installation, repair, or inspection of on-site wastewater systems, to a term that expires on 1 July of years that follow by one year those years that are evenly divisible by three.
  - (5) One member appointed by the General Assembly upon recommendation of the President Pro Tempore of the Senate who, at the time of appointment, is engaged in the business of inspecting on-site wastewater systems, to a term that expires on 1 July of years that precede by one year those years that are evenly divisible by three.
  - (6) One member appointed by the General Assembly upon recommendation of the President Pro Tempore of the Senate upon the recommendation of the North Carolina Home Builders Association, to a term that expires on 1 July of years evenly divisible by three.
  - (7) One member appointed by the General Assembly upon recommendation of the Speaker of the House of Representatives who, at the time of appointment, is engaged in the construction, installation, repair, or inspection of on-site wastewater systems, to a term that expires on 1 July of years evenly divisible by three.
  - (8) One member appointed by the General Assembly upon recommendation of the Speaker of the House of Representatives who, at the time of appointment, is (i) employed as an environmental health specialist, and (ii) engaged primarily in the inspection and permitting of on-site wastewater systems, to a term that expires on 1 July of years that follow by one year those years that are evenly divisible by three.

- (9) One member appointed by the General Assembly upon recommendation of the Speaker of the House of Representatives who, at the time of appointment, is (i) employed by the North Carolina Cooperative Extension Service, and (ii) is knowledgeable in the area of on-site wastewater systems, to a term that expires on 1 July of years that precede by one year those years that are evenly divisible by three.
- (b) Vacancies. – An appointment to fill a vacancy on the Commission created by the resignation, dismissal, disability, or death of a member shall be for the balance of the unexpired term. Vacancies in appointments made by the General Assembly shall be filled as provided in G.S. 120-122.
- (c), (d) Repealed by Session Laws 2010-31, s. 13.2(h), effective July 1, 2010.
- (e) Officers. – The Board shall elect a Chair from among its members. The Chair shall serve from the time of election until 30 June of the following year, or until a successor is elected.
- (f) Compensation. – Board members who are State employees shall receive no per diem compensation for serving on the Board but shall be reimbursed for their expenses in accordance with G.S. 138-6. All other Board members shall receive per diem compensation and reimbursement in accordance with the compensation rate established in G.S. 93B-5.
- (g) Quorum. – A majority of the members of the Board constitutes a quorum for the transaction of business.
- (h) Meetings. – The Board shall meet at least twice each year and may hold special meetings at the call of the Chair or a majority of the members of the Board.
- (i) Repealed by Session Laws 2010-31, s. 13.2(h), effective July 1, 2010. (2006-82, s. 1; 2010-31, ss. 13.2(g), (h); 2011-145, s. 13.3(mm).)

**§ 90A-74. Powers and duties of the Board.**

The Board shall have the following general powers and duties:

- (1) To adopt rules in the manner prescribed by Chapter 150B of the General Statutes to govern its actions and to implement the provisions of this Article.
- (2) To determine the eligibility requirements for persons seeking certification pursuant to this Article.
- (3) To establish grade levels of certifications based on design capacity, complexity, projected costs, and other features of approved on-site wastewater systems.
- (4) To develop and administer examinations for specific grade levels of certification as approved by the Board. The Board may approve applications by recognized associations for certification of its members after a review of the requirements of the association to ensure that they are equivalent to the requirements of the Board.
- (5) To issue, renew, deny, restrict, suspend, or revoke certifications and to carry out any of the other actions authorized by this Article.
- (6) To establish, publish, and enforce rules of professional conduct of persons who are certified pursuant to this Article.
- (7) To maintain a record of all proceedings and make available to persons certified under this Article, and to other concerned parties, an annual report of all Board action.
- (8) To establish reasonable fees for application, certification, and renewal, and other services provided by the Board.
- (9) To conduct investigations to determine whether violations of this Article or grounds for disciplining persons certified under this Article exist.
- (10) To adopt a common seal containing the name of the Board for use on all certificates and official reports issued by the Board.
- (10a) To employ staff necessary to carry out the provisions of this Article and to determine the compensation, duties, and other terms and conditions of employment of its staff.
- (10b) To employ professional, clerical, investigative, or special personnel necessary to carry out the provisions of this Article.
- (11) To conduct other services necessary to carry out the purposes of this Article. (2006-82, s. 1; 2010-31, s. 13.2(i).)

**§ 90A-75. Expenses and fees.**

(a) Expenses. – All salaries, compensation, and expenses incurred or allowed for the purposes of carrying out this Article shall be paid by the Board exclusively out of the funds received by the Board as authorized by this Article. No salary, expense, or other obligations of the Board may be charged against the General Fund of the State.

Neither the Board nor any of its members or employees may incur any expense, debt, or financial obligation binding upon the State.

(b) Contributions. – The Board may accept grants, contributions, devises, and gifts that shall be kept in the same account as the funds deposited in accordance with this Article and other provisions of the law.

(c) Fees. – All fees shall be established in rules adopted by the Board. The Board shall establish fees sufficient to pay the costs of administering this Article, but in no event shall the Board charge a fee at an annual rate in excess of the following:

(1)	Application for basic certification	\$150.00
(2)	Application for each grade level	\$50.00
(3)	Certification renewal	\$100.00
(4)	Reinstatement of revoked or suspended Certification	\$500.00
(5)	Application for on-site wastewater system inspector	\$200.00.

(c1) Use of Fees. – All fees collected pursuant to this Article shall be held by the Board and used by the Board for the sole purpose of administering this Article.

(d) Audit. – The Board is subject to the oversight of the State Auditor under Article 5A of Chapter 147 of the General Statutes. (2006-82, s. 1; 2010-31, s. 13.2(j); 2011-284, s. 66.)

**§ 90A-76:** Repealed by Session Laws 2010-31, s. 13.2(k), effective July 1, 2010.

**§ 90A-77. Certification requirements.**

(a) Certification. – The Board shall issue a certificate of the appropriate grade level to an applicant who satisfies all of the following conditions:

- (1) Is at least 18 years of age.
- (2) Submits a properly completed application to the Board.
- (3) Completes the basic on-site wastewater education program approved by the Board for the specific grade level.
- (4) Repealed by Session Laws 2010-31, s. 13.2(1), effective July 1, 2010.
- (5) Completes any additional training program designed by the Board specific to the grade level for which the applicant is applying.
- (6) Pays the applicable fees set by the Board for the particular application and grade level.
- (7) For the specific grade level, as determined by the Board, passes a written or oral examination that tests the applicant's proficiency in all of the following areas:
  - a. Principles of public and environmental health associated with on-site wastewater systems.
  - b. Principles of construction and safety.
  - c. Technical and practical knowledge of on-site wastewater systems typical to the specified grade level.
  - d. Laws and rules related to the installation, construction, repair, or inspection of the specified on-site wastewater system.

(b) Location of Examinations. – The Board shall provide a minimum of three examinations each year; one each in the eastern, central, and western regions of the State.

(c) Approval of Certification Programs. – The Board may issue a certificate at the appropriate grade level to an applicant who has completed an approved training or continuing education program.

(d) No Degree Required. – An applicant shall not be required to hold or obtain an educational diploma or degree to obtain a certificate. An applicant that meets all the conditions for certification except for passage of the Board examination may take the examination on three successive occasions without having to file for a new application, pay an additional application fee, or repeat any applicable training program. If the applicant fails to pass the Board examination on three successive occasions, the applicant must reapply to the Board, pay an additional application fee, and repeat the training program.

(e) Certificate. – The certification shall show the full name of the certificate holder. The certificate shall provide a unique identification number and shall be signed by the Chair. Issuance of the certificate by the Board shall be prima facie evidence that the person named therein is entitled to all the rights and privileges of a certified contractor or inspector, at the grade level specified on the certificate, while the certificate remains in effect.

(f) Replacement Certificate. – A new certificate to replace one lost, destroyed, or mutilated shall be issued subject to rules adopted by the Board and with the payment of a fee set by the Board. The fee for a duplicate or replacement certificate shall not exceed twenty-five dollars (\$25.00). (2006-82, s. 1; 2010-31, s. 13.2(1).)

**§ 90A-78. Certification renewal.**

(a) Renewal. – All certifications shall expire at intervals determined by the Board unless they are renewed. In no event may the interval determined by the Board be less than one year. To renew a certification, a contractor or inspector must meet all of the following conditions:

- (1) Submit an application for renewal on the form prescribed by the Board.
- (2) Meet the continuing education requirements prescribed by the Board.
- (3) Pay the certification renewal fee.

(b) Late Fee. – A contractor or inspector with an expired certificate may renew the certification within 90 days of its expiration upon payment of a late fee set by the Board. The late fee shall not exceed twenty-five dollars (\$25.00). If a certification is not renewed within 90 days of its expiration, the certification shall not be renewed, and the holder must apply for a new certificate. (2006-82, s. 1.)

**§ 90A-79. Continuing education.**

(a) Requirements. – The Board shall require continuing education as a condition of certification and renewal. The Board shall determine the number of hours, based on grade levels applied for, up to a maximum of 12 hours per year, and the subject material for the specified grade level. The Board shall maintain records of continuing education coursework successfully completed by each certified contractor or inspector.

(b) Approval of Continuing Education Programs. – The Board may approve a continuing education program or course if the Board finds that the program or course provides useful educational information or experience that will enhance the construction, installation, repair, or inspection of on-site wastewater systems. The Board may develop and offer continuing education programs. (2006-82, s. 1.)

**§ 90A-80. Investigation of complaints.**

(a) Misconduct. – A person may refer to the Board charges of fraud, deceit, negligence, incompetence, or misconduct against any certified contractor or inspector. The charges shall be in writing and sworn to by the complainant and submitted to the Board. These charges, unless dismissed without a hearing by the Board as unfounded or trivial, shall be heard and determined by the Board in accordance with the provisions of Chapter 150B of the General Statutes. An association that receives professional recognition of its own certification process by the Board shall be responsible for the conduct and competency of its members.

(b) Records. – The Board shall establish and maintain detailed records regarding complaints concerning each certified contractor or inspector. The records shall include those certified by recognized associations. The records shall also detail the levels of certification held by each contractor or inspector.

(c) Notification. – The Board shall provide local health departments with notification of changes in certifications, complaints, suspensions, or reinstatements under this Article. (2006-82, s. 1.)

**§ 90A-81. Remedies.**

(a) Denial, Suspension, and Revocation of Certification. – The Board may deny, suspend, or revoke a certificate under this Article for:

- (1) A violation of this Article or a rule of the Board.
- (2) The use of fraud or deceit in obtaining or renewing a certificate.
- (3) Any act of gross negligence, incompetence, or misconduct in the construction, installation, repair, or inspection of an on-site wastewater system.
- (4) Failure to satisfactorily complete continuing education requirements prescribed by the Board.

(b) Arbitration. – The Board may establish a voluntary arbitration procedure to resolve complaints concerning a certified contractor or inspector or any work performed by a certified contractor or inspector, or conflicts involving any certified contractor or inspector and the Division of Public Health of the Department or a local health department.

(c) Injunction. – The Board may in its own name seek an injunction to restrain any person, firm, partnership, or corporation from violating the provisions of this Article or rules adopted by the Board. The Board may bring an action for an injunction in the superior court of any county in which the violator resides or the violator's principal place of business is located. In any proceedings for an injunction, it shall not be necessary to allege or prove either that an adequate remedy at law does not exist, or that substantial or irreparable damage would result from the continued violation. Members of the Board shall not be personally or professionally liable for any act or omission pursuant to this subsection. The Board shall not be required to post a bond in connection with any action to obtain an injunction.

(d) Offenses. – A person who commits any one or more of the following offenses is guilty of a Class 2 misdemeanor:

- (1) Engages in or offers to engage in the construction, installation, repair, or inspection of an on-site wastewater system without the appropriate certificate for the grade level of on-site wastewater system.
- (2) Gives false or forged evidence of any kind in obtaining a certificate.
- (3) Falsely impersonates a certified contractor or inspector. (2006-82, s. 1; 2010-31, s. 13.2(m); 2011-145, s. 13.3(m).)

**SESSION LAW 2004-140 (signed into law July 29, 2004)**

AN ACT TO SPECIFY THE MINIMUM HORIZONTAL SEPARATION DISTANCES BETWEEN A SUBSURFACE WASTEWATER DISPOSAL SYSTEM TO BE LOCATED ON A LOT OR TRACT OF LAND PLATTED PRIOR TO 1 JULY 1977, THAT WILL BE OPERATED IN SAND OR LOAMY SAND SOILS, AND THAT MEETS CERTAIN OTHER REQUIREMENTS, AND ANY OTHER SUBSURFACE WASTEWATER DISPOSAL SYSTEM.

The General Assembly of North Carolina enacts:

SECTION 1. A subsurface wastewater disposal system shall be located the maximum feasible horizontal distance, but not less than 10 feet from any other subsurface wastewater disposal system, when all of the following conditions are met:

- (1) The lot or tract of land on which the system will be located is specifically described in a deed, other instrument conveying fee simple title, or on a plat recorded prior to 1 July 1977.
- (2) The lot or tract of land is of insufficient size to allow the minimum horizontal separation distance for a conventional wastewater system required in 15A NCAC 18A .1950.
- (3) The system will receive sewage from only one single-family residence not to exceed four bedrooms.
- (4) The residence is not capable of being served by a public or community wastewater system at the time construction of the system commences.
- (5) The system will be installed in sand or loamy sand soils as defined in 15A NCAC 18A .1935 and installed in accordance with rules adopted pursuant to Article 11 of Chapter 130A of the General Statutes.

SECTION 2. The Commission for Health Services may adopt rules that incorporate the provisions of Section 1 of this act. Except as provided by Section 1 of this act, this act does not limit the authority of the Commission for Health Services or the Environmental Management Commission to adopt rules governing the location, construction, operation, maintenance, or repair of subsurface wastewater disposal systems pursuant to G.S. 130A-335 or other provisions of Article 11 of Chapter 130A of the General Statutes.

SECTION 3. This act is effective when it becomes law and applies to applications for permits made on or after that date. If the Commission for Health Services adopts a permanent rule to implement the provisions of Section 1 of this act, Section 1 of this act expires when the permanent rule becomes effective.

**SESSION LAW 2008-143 (House Bill 2499, signed into law July 31, 2008)**

AN ACT TO IMPROVE DROUGHT PREPAREDNESS AND RESPONSE IN NORTH CAROLINA, AS RECOMMENDED BY THE ENVIRONMENTAL REVIEW COMMISSION.

**SECTION 14.(a)** For purposes of this section, "gray water" means wastewater removed from household wash basins, bathtubs, and showers.

**SECTION 14.(b)** The Commission for Health Services shall adopt rules to authorize the use of gray water during periods of drought to hand water trees, shrubs, and inedible plants on single-family residential property. The rules shall encourage the use of gray water as provided in this section while protecting public health, safety, welfare, and the environment. In developing the rules, the Commission shall review the provisions set out in subsection (c) of this section.

**SECTION 14.(c)** Notwithstanding G.S. 130A-335(a), untreated gray water may be used in periods of drought to hand water trees, shrubs, and inedible plants on single-family residential property under the following conditions:

- (1) Gray water shall be applied as soon as practicable. Untreated gray water should not be stored for later use.
- (2) Gray water containing hazardous chemicals including, but not limited to, residue from solvents shall not be used.
- (3) Use of untreated gray water is restricted to the residential property where the gray water originates. Untreated gray water shall not be allowed to run off onto adjoining property, roadways, or into drainage features such as ditches and storm drains.
- (4) Untreated gray water shall be applied using buckets, watering cans, or other handheld containers. Gray water may not be used in an irrigation system unless the gray water has been treated in accordance with standards set out in the State Plumbing Code.
- (5) Gray water shall not be applied closer than 100 feet to surface waters or a water supply well

**SESSION LAW 2010-177 (House Bill 683, signed into law August 2, 2010)**

AN ACT TO AMEND THE PERMIT EXTENSION ACT OF 2009.

The General Assembly of North Carolina enacts:

**SECTION 1.** S.L. 2009-406, as amended by Section 5.1 of S.L. 2009-484, Section 5.2 of S.L. 2009-550, and Sections 2 and 3 of S.L. 2009-572, reads as rewritten:

"**SECTION 1.** This act shall be known and may be cited as the "Permit Extension Act of 2009."

"**SECTION 2.** The General Assembly makes the following findings:

- (1) There exists a state of economic emergency in the State of North Carolina and the nation, which has drastically affected various segments of the North Carolina economy, but none as severely as the State's banking, real estate, and construction sectors.
- (2) The real estate finance sector of the economy is in severe decline due to the creation, bundling, and widespread selling of leveraged securities, such as credit default swaps, and due to excessive defaults on sub-prime mortgages and the resultant foreclosures on a vast scale, thereby widening the mortgage finance crisis. The extreme tightening of lending standards for home buyers and other real estate borrowers has reduced access to the capital markets.
- (3) As a result of the crisis in the real estate finance sector of the economy, real estate developers and redevelopers, including home builders, and commercial, office, and industrial developers, have experienced an industry-wide decline, including reduced demand, cancelled orders, declining sales and rentals, price reductions, increased inventory, fewer buyers who qualify to purchase homes, layoffs, and scaled back growth plans.
- (4) The process of obtaining planning board and zoning board of adjustment approvals for subdivisions, site plans, and variances can be difficult, time consuming, and expensive, both for private applicants and government bodies.
- (5) The process of obtaining the myriad of other government approvals, such as wetlands permits, treatment works approvals, on-site wastewater disposal permits, stream encroachment permits, flood hazard area permits, highway access permits, and numerous waivers and variances, can be difficult and expensive; further, changes in the law can render these approvals, if expired or lapsed, difficult to renew or reobtain.
- (6) County and municipal governments, including local sewer and water authorities, obtain permits and approvals from State government agencies, particularly the Department of Environment and Natural Resources, which permits and approvals may expire or lapse due to the state of the economy and the inability of both the public sector and the private sector to proceed with projects authorized by the permit or approval.
- (7) County and municipal governments also obtain determinations of master plan consistency, conformance, or endorsement with State or regional plans, from State and regional government entities that may expire or lapse without implementation due to the state of the economy.
- (8) The current national recession has severely weakened the building industry, and many landowners and developers are seeing their life's work destroyed by the lack of credit and dearth of buyers and tenants due to the crisis in real estate financing and the building industry, uncertainty over the state of the economy, and increasing levels of unemployment in the construction industry.
- (9) The construction industry and related trades are sustaining severe economic losses, and the lapsing of government development approvals would exacerbate, if not addressed, those losses.
- (10) Financial institutions that lent money to property owners, builders, and developers are experiencing erosion of collateral and depreciation of their assets as permits and approvals expire, and the extension of these permits and approvals is necessary to maintain the value of the collateral and the solvency of financial institutions throughout the State.
- (11) Due to the current inability of builders and their purchasers to obtain financing under existing economic conditions, more and more once-approved permits are expiring or lapsing, and, as these approvals lapse, lenders must reappraise and thereafter substantially lower real estate valuations established in conjunction with approved projects, thereby requiring the reclassification of numerous loans, which, in turn, affects the stability of the banking system and reduces the funds available for future lending, thus creating more severe restrictions on credit and leading to a vicious cycle of default.
- (12) As a result of the continued downturn of the economy and the continued expiration of approvals that were granted by State and local governments, it is possible that thousands of government actions will be undone by the passage of time.

- (13) Obtaining an extension of an approval pursuant to existing statutory or regulatory provisions can be both costly in terms of time and financial resources and insufficient to cope with the extent of the present financial conditions; moreover, the costs imposed fall on the public as well as the private sector.
- (14) It is the purpose of this act to prevent the wholesale abandonment of already approved projects and activities due to the present unfavorable economic conditions by tolling the term of these approvals for a finite period of time as the economy improves, thereby preventing a waste of public and private resources.

**"SECTION 3.** Definitions. – As used in this act, the following definitions apply:

- (1) Development approval. – Any of the following approvals issued by the State, any agency or subdivision of the State, or any unit of local government, regardless of the form of the approval, that are for the development of land or for the provision of water or wastewater services by a government entity:
- a. Any detailed statement by a State agency under G.S. 113A-4.
  - b. Any detailed statement submitted by a special purpose unit of government or a private developer of a major development project under G.S. 113A-8.
  - c. Any finding of no significant impact prepared by a State agency under Article 1 of Chapter 113A of the General Statutes.
  - d. Any approval of an erosion and sedimentation control plan granted by a local government or by the North Carolina Sedimentation Control Commission under Article 4 of Chapter 113A of the General Statutes.
  - e. Any permit for major development or minor development, as defined in G.S. 113A-118, or any other permit issued under the Coastal Area Management Act (CAMA), Part 4 of Article 7 of Chapter 113A of the General Statutes.
  - f. Any water or wastewater permit issued under Article 10 or Article 11 of Chapter 130A of the General Statutes.
  - g. Any building permit issued under Article 9 of Chapter 143 of the General Statutes.
  - h. Any nondischarge or extension permit issued under Part 1 of Article 21 of Chapter 143 of the General Statutes.
  - i. Any stream origination certifications issued under Article 21 of Chapter 143 of the General Statutes.
  - j. Any water quality certification under Article 21 of Chapter 143 of the General Statutes.
  - k. Any air quality permit issued by the Environmental Management Commission under Article 21B of Chapter 143 of the General Statutes.
  - l. Any approval by a county of sketch plans, preliminary plats, plats regarding a subdivision of land, a site specific development plan or a phased development plan, a development permit, a development agreement, or a building permit under Article 18 of Chapter 153A of the General Statutes.
  - m. Any approval by a city of sketch plans, preliminary plats, plats regarding a subdivision of land, a site specific development plan or a phased development plan, a development permit, a development agreement, or a building permit under Article 19 of Chapter 160A of the General Statutes.
  - n. Any certificate of appropriateness issued by a preservation commission of a city under Part 3C of Article 19 of Chapter 160A of the General Statutes.
- (2) Development. – The division of a parcel of land into two or more parcels, the construction, reconstruction, conversion, structural alteration, relocation, or enlargement of any building or other structure or facility, or any grading, soil removal or relocation, excavation or landfill, or any use or change in the use of any building or other structure or land or extension of the use of land.

**"SECTION 4.** For any development approval that is current and valid at any point during the period beginning January 1, 2008, and ending December 31, 2010, the running of the period of the development approval and any associated vested right under G.S. 153A-344.1 or G.S. 160A-385.1 is suspended during the period beginning January 1, 2008, and ending December 31, ~~2010~~ 2011.

**"SECTION 4.1.** A unit of local government may by resolution provide that S.L. 2009-406, as amended by Section 5.1 of S.L. 2009-484, Section 5.2 of S.L. 2009-550, Sections 2 and 3 of S.L. 2009-572, and by this act, shall not apply to a development approval issued by that unit of local government. A development approval issued by a unit of local government that opts out pursuant to this section shall expire as it was scheduled to expire pursuant to S.L. 2009-406, as amended by Section 5.1 of S.L. 2009-484, Section 5.2 of S.L. 2009-550, and Sections 2 and 3 of S.L. 2009-572 prior to the enactment of this act.

**"SECTION 5.** This act shall not be construed or implemented to:

- (1) Extend any permit or approval issued by the United States or any of its agencies or instrumentalities.
- (2) Extend any permit or approval for which the term or duration of the permit or approval is specified or determined pursuant to federal law.
- (3) Shorten the duration that any development approval would have had in the absence of this act.
- (4) Prohibit the granting of such additional extensions as are provided by law.
- (5) Affect any administrative consent order issued by the Department of Environment and Natural Resources in effect or issued at any time from the effective date of this act to December 31, ~~2010~~ 2011.
- (6) Affect the ability of a government entity to revoke or modify a development approval or to accept voluntary relinquishment of a development approval by the holder of the development approval pursuant to law.
- (7) Modify any requirement of law that is necessary to retain federal delegation by the State of the authority to implement a federal law or program.
- (8) Modify any person's obligations or impair the rights of any party under contract, including bond or other similar undertaking.
- (9) Authorize the charging of a water or wastewater tap fee that has been previously paid in full for a project subject to a development approval.

**"SECTION 5.1.(a)** This act does not revive a vested right to the water or sewer allocation associated with a development approval that expired between January 1, 2008, and August 5, 2009, and is revived by the operation of this act if both of the following conditions are met:

- (1) The water or sewer capacity was reallocated to other development projects prior to August 5, 2009, based upon the expiration of the development approval.
- (2) There is not sufficient supply or treatment capacity to accommodate the project that is the subject of the revived development approval.

**"SECTION 5.1.(b)** A person whose development approval is revived under this act but whose water or sewer allocation is not revived under this section must be given first priority if additional supply or treatment capacity becomes available.

**"SECTION 5.2.(a)** This section applies only to Union County.

**"SECTION 5.2.(b)** When a development approval that is contingent upon connection to a water supply system or a sanitary sewer system is suspended under Section 4 of this act and there is not sufficient supply or treatment capacity to accommodate requests for additional allocation, the local government that granted the allocation may reallocate requested capacity from projects whose approvals are suspended but are not ready to proceed, if the local government meets all of the following requirements:

- (1) Establishes an allocation plan for existing capacity that determines actual capacity and provides for a fair and equitable process to distribute the remaining capacity.
- (2) Establishes a reallocation plan to meet requests for capacity above permitted capacity that is fair and equitable and requires the following:
  - a. That an applicant for a new or additional allocation demonstrate the ability to begin construction.
  - b. That the holder of a development permit suspended under Section 4 of this act demonstrate the ability or intent to begin construction in no less than 120 days in order to retain the reserved capacity.
- (3) Does not reallocate capacity to exceed the amount of the reserved capacity.

**"SECTION 5.2.(c)** This act does not reduce the original period of a development permit.

**"SECTION 6.** Within 30 days after the effective date of this act, each agency or subdivision of the State to which this act applies shall place a notice in the North Carolina Register listing the types of development approvals that the agency or subdivision issues and noting the extension provided in this act. This section does not apply to units of local government.

**"SECTION 7.** The provisions of this act shall be liberally construed to effectuate the purposes of this act.

**"SECTION 7.1. Conditions for qualification; termination; right of appeal.**

(a) For any development approval extended by S.L. 2009-406, as amended by Section 5.1 of S.L. 2009-484, Section 5.2 of S.L. 2009-550, Sections 2 and 3 of S.L. 2009-572, and by this act, the holder of the development approval shall:

- (1) Comply with all applicable laws, regulations, and policies in effect at the time the development approval was originally issued by the governmental entity.
- (2) Maintain all performance guarantees that are imposed as a condition of the initial development approval for the duration of the period the development approval is extended or until affirmatively released from that obligation by the issuing governmental entity.

- (3) Complete any infrastructure necessary in order to obtain a certificate of occupancy or other final permit approval from the issuing governmental entity.
- (b) Failure to comply with any condition in this section may result in termination of the extension of the development approval by the issuing governmental entity. In the event of a termination of the extension of a development approval, the issuing governmental entity shall provide written notice to the last known address of the original holder of the development approval of the termination of the extension of the development approval, including the reason for the termination.
- (c) Termination of an extension of a development approval shall be subject to appeal to the Board of Adjustment under the requirements set forth in law if the development approval was issued by a unit of local government with planning authority under Article 18 of Chapter 153A or Article 19 of Chapter 160A of the General Statutes.

"**SECTION 8.** This act is effective when it becomes law."

**SECTION 2.** This act is effective when it becomes law.

**SESSION LAW 2011-394 (House Bill 119, declared to have become a law July 1, 2011)**

**AN ACT TO AMEND CERTAIN ENVIRONMENTAL AND NATURAL RESOURCES LAWS TO**

*(Only sections relevant to On-Site Wastewater Program)*

**(12) PROMOTE THE USE OF GRAY WATER**

The General Assembly of North Carolina enacts:

**SECTION 12.(a)** G.S. 143-350 reads as rewritten:

**"§ 143-350. Definitions.**

As used in this Article:

...

(3a) "Gray water" means water that is discharged as waste from bathtubs, showers, wash basins, and clothes washers. "Gray water" does not include water that is discharged from toilets or kitchen sinks.

(3b) "Gray water system" means a water reuse system that is contained within a single family residence or multiunit residential or commercial building that filters gray water or captured rain water and reuses it for nonpotable purposes such as toilet flushing and irrigation.

...."

**SECTION 12.(b)** G.S. 143-355.5 reads as rewritten:

**"§ 143-355.5. Water reuse; policy; rule making.**

(a) **Water Reuse Policy.** – It is the public policy of the State that the reuse of treated wastewater or reclaimed water and the use of gray water or captured rain water is critical to meeting the existing and future water supply needs of the State. The General Assembly finds that reclaimed water systems permitted and operated under G.S. 143-215.1(d2) in an approved wastewater reuse program can provide water for many beneficial purposes in a way that is both environmentally acceptable and protective of public health. This finding includes and applies to conjunctive facilities that require the relocation of a discharge from one receiving stream to another under all of the following conditions:

- (1) The relocation is necessary to create an approved comprehensive wastewater reuse program.
- (2) The reuse program provides significant reuse benefits.
- (3) The relocated discharge will comply with all applicable water quality standards; will not result in degradation of water quality in the receiving waters; will not contribute to water quality impairment in the receiving watershed; and will result in net benefits to water quality, such as the elimination of a wastewater discharge in a nutrient sensitive river basin.

(b) **Water Reuse Rule Making.** – The Commission shall encourage and promote safe and beneficial reuse of treated wastewater as an alternative to surface water discharge. The Commission shall adopt rules to:

Page 14 Session Law 2011-394 SL2011-0394

- (1) Identify acceptable uses of reclaimed water, including toilet flushing, fire protection, decorative water features, and landscape irrigation.
- (2) Facilitate the permitting of reclaimed water systems.
- (3) Establish standards for reclaimed water systems that are adequate to prevent the direct distribution of reclaimed water as potable water.

(c) **Gray Water Rule Making.** – The Commission shall encourage and promote the safe and beneficial use of gray water. The Commission shall adopt rules to:

- (1) Identify acceptable uses of gray water, including toilet flushing, fire protection, decorative water features, and landscape irrigation.
- (2) Facilitate the permitting of gray water systems.
- (3) Establish standards, in coordination with the Commission for Public Health, for gray water systems that protect public health and safety and the environment and reduce the use of potable water within individual structures.

(d) The Department shall develop policies and procedures to promote the voluntary adoption and installation of gray water systems."

**SECTION 12.(c)** G.S. 130A-335(b) reads as rewritten:

"(b) All wastewater systems shall be regulated by the Department under rules adopted by the Commission except for the following wastewater systems that shall be regulated by the Department under rules adopted by the Environmental Management Commission:

- (1) Wastewater collection, treatment, and disposal systems designed to discharge effluent to the land surface or surface waters.
- (2) Wastewater systems designed for groundwater remediation, groundwater injection, or landfill leachate collection and disposal.
- (3) Wastewater systems designed for the complete recycle or reuse of industrial process wastewater.
- (4) Gray water systems as defined in G.S. 143-350.

**SECTION 12.(d)** Article 6 of Chapter 153A of the General Statutes is amended by adding a new section to read:

**"§ 153A-145. Limitations on regulating cisterns and rain barrels.**

No county ordinance may prohibit or have the effect of prohibiting the installation and maintenance of cisterns and rain barrel collection systems used to collect water for irrigation purposes. A county may regulate the installation and maintenance of those cisterns and rain barrel collection systems for the purpose of protecting the public health and safety and for the purpose of preventing them from becoming a public nuisance."

**SECTION 12.(e)** Article 8 of Chapter 160A of the General Statutes is amended by adding a new section to read:

**"§ 160A-202. Limitations on regulating cisterns and rain barrels.**

No city ordinance may prohibit or have the effect of prohibiting the installation and maintenance of cisterns and rain barrel collection systems used to collect water for irrigation purposes. A city may regulate the installation and maintenance of those cisterns and rain barrel collection systems for the purpose of protecting the public health and safety and for the purpose of preventing them from becoming a public nuisance."

**SECTION 24.** Except as otherwise provided, this act is effective when it becomes law. Section 8(b) of this act applies to every major facility construction project, as defined in G.S. 143-135.36, and every major facility renovation project, as defined in G.S. 143-135.36, of a public agency, as defined in G.S. 143-135.36, that has not entered the schematic design phase prior to the effective date of this act.

In the General Assembly read three times and ratified this the 18th day of June, 2011.

**SESSION LAW 2011-41 (House Bill 162, signed into law August 2, 2010)**

**AN ACT TO EXEMPT CERTAIN ACTIVITIES RELATED TO SMALL-SCALE PROCESSING OF AGRICULTURAL PRODUCTS FROM WASTEWATER PERMIT REQUIREMENTS.**

The General Assembly of North Carolina enacts:

**SECTION 1.** G.S. 143-215.1 is amended by adding a new subsection to read:

"(a5) For purposes of this subsection, "agricultural products" means horticultural, viticultural, forestry, dairy, livestock, poultry, bee, and any farm products. Notwithstanding subsection (a) of this section, a permit shall not be required for a wastewater management system for the treatment and disposal of wastewater produced from activities related to the processing of agricultural products if all of the following conditions are met:

- (1) The activities related to the processing of the agricultural products are carried out by the owner of the agricultural products.
- (2) The activities related to the processing of the agricultural products produce no more than 1,000 gallons of wastewater per day.
- (3) The wastewater is not generated by an animal waste management system as defined in G.S. 143-215.10B.
- (4) The wastewater is disposed of by land application.
- (5) No wastewater is discharged to surface waters.
- (6) The disposal of the wastewater does not result in any violation of surface water or groundwater standards."

**SECTION 2.** This act is effective when it becomes law.

**SESSION LAW 2013-413 (House Bill 74, became law August 23, 2013)**

AN ACT TO IMPROVE AND STREAMLINE THE REGULATORY PROCESS IN ORDER TO STIMULATE JOB CREATION, TO ELIMINATE UNNECESSARY REGULATION, TO MAKE VARIOUS OTHER STATUTORY CHANGES, AND TO AMEND CERTAIN ENVIRONMENTAL AND NATURAL RESOURCES LAWS

*(Only sections relevant to On-Site Wastewater Program copied herein)*

**PROVIDE FOR LOW-FLOW DESIGN ALTERNATIVES FOR WASTEWATER SYSTEMS**

*(Note: Includes more recent Modification to Section 34.(b) made under Session Law 2014-120, signed into law September 18, 2014)*

**SECTION 34.(a)** 15A NCAC 18A .1949(b) (Sewage Flow Rates for Design Units). – Until the effective date of the revised permanent rule that the Commission is required to adopt pursuant to Section 34(c) of this act, the Commission, the Department, and any other political subdivision of the State shall implement 15A NCAC 18A .1949(b) (Sewage Flow Rates for Design Units) as provided in Section 34(b) of this act.

**From Session Law 2014-120:** “**SECTION 53:** Section 34(b) of S.L. 2013-413 reads as rewritten:

**SECTION 34.(b)** Implementation. – Notwithstanding the Daily Flow for Design rates listed for dwelling units in 15A NCAC 18A .1949(a) or for other establishments in Table No. 1 of 15A NCAC 18A .1949(b) (Sewage Flow Rates for Design Units), a wastewater system shall be exempt from the Daily Flow for Design, and any other design flow standards that are established by the Department of Health and Human Services or the Commission for Public Health provided flow rates that are less than those listed in ~~Table No. 1 of 15A NCAC 18A .1949(b)~~ 15A NCAC 18A .1949 (Sewage Flow Rates for Design Units) can be achieved through engineering design that utilizes low-flow fixtures and low-flow technologies and the design is prepared, sealed, and signed by a professional engineer licensed pursuant to Chapter 89C of the General Statutes. The Department and Commission may ~~establish~~ establish, by rule, lower limits on reduced flow rates as necessary to ensure wastewater system integrity and protect public health, safety, and ~~welfare~~ welfare, provided that the Commission relies on scientific evidence specific to soil types found in North Carolina that the lower limits are necessary for those soil types. Rules adopted pursuant to this section shall become effective as provided in G.S. 150B-21.3(b1) as though 10 or more written objections had been received as provided by G.S. 150B-21.3(b2). Proposed daily design flows for wastewater systems that are calculated to be less than 3,000 total gallons per day shall not require State review pursuant to 15A NCAC 18A .1938(e). Neither the State nor any local health department shall be liable for any damages caused by a system approved or permitted pursuant to this section.”

**From Session Law 2013-413, continued:**

**SECTION 34.(c)** Additional Rule-Making Authority. – The Commission shall adopt a rule to amend 15A NCAC 18A .1949(b) (Sewage Flow Rates for Design Units) consistent with Section 34(b) of this act. Notwithstanding G.S. 150B-19(4), the rule adopted by the Commission pursuant to this section shall be substantively identical to the provisions of Section 34(b) of this act. Rules adopted pursuant to this section are not subject to G.S. 150B-21.8 through G.S. 150B-21.14. Rules adopted pursuant to this section shall become effective as provided in G.S. 150B-21.3(b1) as though 10 or more written objections had been received as provided by G.S. 150B-21.3(b2).

**SECTION 34.(d)** Sunset. – Section 34(b) of this act expires on the date that rules adopted pursuant to Section 34(c) of this act become effective.

**SESSION LAW 2014-120 (Senate Bill 734, signed into law September 18, 2014)**

AN ACT TO PROVIDE FURTHER REGULATORY RELIEF TO THE CITIZENS OF NORTH CAROLINA BY PROVIDING FOR VARIOUS ADMINISTRATIVE REFORMS, BY ELIMINATING CERTAIN UNNECESSARY OR OUTDATED STATUTES AND REGULATIONS AND MODERNIZING OR SIMPLIFYING CUMBERSOME OR OUTDATED REGULATIONS, AND BY MAKING VARIOUS OTHER STATUTORY CHANGES.

*(Only sections relevant to On-Site Wastewater Program copied herein)*

The General Assembly of North Carolina enacts

**REFORM AGENCY REVIEW OF ENGINEERING WORK**

**SECTION 29.(a)** Definitions. – The following definitions apply to Section 6 of this act:

- (1) Practice of Engineering. – As defined in G.S. 89C-3.
- (2) Professional Engineer. – As defined in G.S. 89C-3.
- (3) Regulatory Authority. – The Department of Environment and Natural Resources, the Department of Health and Human Services, and any unit of local government operating a program (i) that grants permits, licenses, or approvals to the public and (ii) that is either approved by or delegated from the Department of Environment and Natural Resources or the Department of Health and Human Services.
- (4) Regulatory Submittal. – An application or other submittal to a Regulatory Authority for a permit, license, or approval. In the case of a unit of local government, Regulatory Submittal shall mean an application or submittal submitted to a program approved by or delegated from the Department of Environment and Natural Resources or the Department of Health and Human Services.
- (5) Submitting Party. – The person submitting the Regulatory Submittal to the Regulatory Authority.
- (6) Working Job Title. – The job title a Regulatory Authority uses to publicly identify an employee with job duties that include the review of Regulatory Submittals. Working Job Title does not mean job titles that are used by the human resources department of a Regulatory Authority to classify jobs containing technical aspects related to the Practice of Engineering.

**SECTION 29.(b)** Standardize Certain Regulatory Review Procedures. – No later than December 1, 2014, each Regulatory Authority shall review and, where necessary, revise its procedures for review of Regulatory Submittals to accomplish the following:

- (1) Standardize the provision of review and comments on Regulatory Submittals so that revisions or requests for additional information that are required by the Regulatory Authority in order to proceed with the permit, license, or approval are clearly delineated from revisions or requests for additional information that constitute suggestions or recommendations by the Regulatory Authority. For purposes of this subdivision, "suggestions or recommendations by the Regulatory Authority" means comments made by the reviewer of the Regulatory Submittal to the Submitting Party that make a suggestion or recommendation for consideration by the Submitting Party but that are not required by the Regulatory Authority in order to proceed with the permit, license, or approval.
- (2) With respect to revisions or requests for additional information that are required by the Regulatory Authority in order to proceed with the permit, license, or approval, the Regulatory Authority shall identify the statutory or regulatory authority for the requirement.

**SECTION 29.(c)** Informal Review. – No later than December 1, 2014, each Regulatory Authority shall create a process for each regulatory program administered by the Regulatory Authority for an informal internal review at the request of the Submitting Party in each of the following circumstances:

- (1) The inclusion in a Regulatory Submittal of a design or practice sealed by a Professional Engineer but not included in the Regulatory Authority's existing guidance, manuals, or standard operating procedures. This review should first be conducted by the reviewing employee's supervisor or, in the case of a Regulatory Authority that is a unit of local government, either the reviewing employee's supervisor or the delegating or approving State agency. If this initial review was not conducted by a Professional Engineer, then the Submitting Party may request review by (i) a Professional Engineer on the staff of the Regulatory Authority or (ii) the delegating or approving State agency in the case of a Regulatory Authority that is a unit of local government. If the Regulatory Authority or delegating or approving State agency does not employ a Professional Engineer qualified and competent to perform the review, it may provide for review by a consulting Professional Engineer selected from a list developed and maintained by the Regulatory Authority. The Regulatory Authority may charge the Submitting Party for the costs of the review by the consulting Professional Engineer. Nothing in this subdivision is intended to limit the authority of the Regulatory Authority to make a final decision with regard to a Regulatory Submittal following the reviews described in this subdivision.

(2) A disagreement between the reviewer of the Regulatory Submittal and the Submitting Party regarding whether the statutory or regulatory authority identified by the Regulatory Authority for revisions or requests for additional information designated as "required" under the procedures set forth in Section 29(b) of this act justifies a required change.

**SECTION 29.(d) Scope.** – Nothing in Section 29(c) of this act shall limit or abrogate any rights available under Chapter 150B of the General Statutes to any Submitting Party.

**SECTION 29.(e) Procedure to Develop List of Consulting Professional Engineers.** – Regulatory Authorities shall develop formal written procedures to prepare and maintain a list of consulting Professional Engineers required pursuant to subdivision (1) of Section 29(c) of this act.

**SECTION 29.(f) Pilot Study.** – No later than March 1, 2015, the Department of Environment and Natural Resources shall complete a pilot study on the Pretreatment, Emergency Response and Collection System (PERCS) wastewater collection system permitting program and the stormwater permitting program and perform the following activities with the assistance and cooperation of the North Carolina Board of Examiners for Engineers and Surveyors and the Professional Engineers of North Carolina:

- (1) Produce an inventory of work activities associated with the operation of each regulatory program.
- (2) Determine the work activities identified under subdivision (1) of this subsection that constitute the Practice of Engineering.
- (3) Develop recommendations for ensuring that work activities constituting the Practice of Engineering are conducted with the appropriate level of oversight.

**SECTION 29.(g) Report.** – The Department shall report the results of the pilot study to the Environmental Review Commission no later than April 15, 2015.

**SECTION 29.(h) Review of Working Job Titles.** – No later than December 1, 2014, each Regulatory Authority and the Department of Transportation shall do the following:

- (1) Review the Working Job Titles of every employee with job duties that include the review of Regulatory Submittals.
- (2) Propose revisions to the Working Job Titles identified under subdivision (1) of this subsection or other administrative measures that will eliminate the public identification as "engineers" of persons reviewing Regulatory Submittals who are not Professional Engineers.

**SECTION 29.(i) Initial Report.** – Each Regulatory Authority shall report to the Environmental Review Commission prior to the convening of the 2015 Regular Session of the 2015 General Assembly on implementation of the following, if applicable:

- (1) The standardized procedures required by Section 29(b) of this act.
- (2) The informal review process required by Section 29(c) of this act.
- (3) The review of Working Job Titles required by Section 29(h) of this act.

**SECTION 29.(j) Annual Report.** – Beginning in 2016, each Regulatory Authority shall annually report to the Environmental Review Commission no later than January 15 on the informal review process required by Section 29(c) of this act. The report shall include the number of times the informal review process was utilized and the outcome of the review.

**SECTION 29.(k) Annual Reporting Sunset.** – Section 29(j) of this act expires on January 1, 2019.

## **MODIFICATION OF APPROVED WASTEWATER SYSTEMS**

**SECTION 47.(a)** The definitions set out in G.S. 130A-343 shall apply to this section.

**SECTION 47.(b)** 15A NCAC 18A .1969(j) (Modification of Approved Systems). – Until the effective date of the revised permanent rule that the Commission is required to adopt pursuant to Section 47(d) of this act, the Commission and the Department shall implement 15A NCAC 18A .1969(j) (Modification of Approved Systems) as provided in Section 47(c) of this act.

**SECTION 47.(c) Implementation.** – Notwithstanding 15A NCAC 18A .1969(j) (Modification of Approved Systems), the rule shall be implemented so as to not require a survey or audit of installed modified accepted systems in order to confirm the satisfactory performance of such systems.

**SECTION 47.(d) Additional Rule-Making Authority.** – The Commission for Public Health shall adopt a rule to amend 15A NCAC 18A .1969(j) (Modification of Approved Systems) consistent with Section 47(c) of this act. Notwithstanding G.S. 150B-19(4), the rule adopted by the Commission pursuant to this section shall be substantively identical to the provisions of Section 47(c) of this act. Rules adopted pursuant to this section are not subject to Part 3 of Article 2A of Chapter 150B of the General Statutes. Rules adopted pursuant to this section shall become effective as provided in G.S. 150B-21.3(b1) as though 10 or more written objections had been received as provided by G.S. 150B-21.3(b2).

**SECTION 47.(e) Sunset.** – Section 47(c) of this act expires on the date that the rule adopted pursuant to Section 47(d) of this act becomes effective.

**EXPAND DAILY FLOW DESIGN EXEMPTION FOR LOW-FLOW FIXTURES**

**SECTION 53.** (This Modification to Section 34(b) of S.L. 2013-413 was reproduced with other related material, above):

**SECTION 61.** Except as otherwise provided, this act is effective when it becomes law.

**SESSION LAW 2014-122 COAL ASH MANAGEMENT ACT OF 2014 (Senate Bill 729, declared to have become law September 20, 2014)**

*(Only sections relevant to On-Site Wastewater Program copied herein)*

PART VII. AMEND COMPLIANCE BOUNDARY PROVISIONS [*Note: Includes more recent Modification to G.S. 143-215.1(k) made in Section 3.5, Session Law 2015-1, signed into law March 16, 2015*]

**SECTION 12.(a)** G.S. 143-215.1 reads as rewritten:

**"§ 143-215.1. Control of sources of water pollution; permits required.**

...

(i) Any person subject to the requirements of this section who is required to obtain an individual permit from the Commission for a disposal system under the authority of G.S. 143-215.1 or Chapter 130A of the General Statutes shall have a compliance boundary as may be established by rule or permit for various categories of disposal systems and beyond which groundwater quality standards may not be exceeded. ~~The location of the compliance boundary shall be established at the property boundary, except as otherwise established by the Commission.~~ Multiple contiguous properties under common ownership and permitted for use as a disposal system shall be treated as a single property with regard to determination of a compliance boundary under this subsection. ~~Nothing in this subsection shall be interpreted to require a revision to an existing compliance boundary previously approved by rule or permit boundary.~~

(j) ~~When operation of a disposal system permitted under this section results in an exceedance of the groundwater quality standards adopted in accordance with G.S. 143-214.1, the Commission shall require that the exceedances within the compliance boundary be remedied through cleanup, recovery, containment, or other response only when any of the following conditions occur:~~

~~(1) A violation of any water quality standard in adjoining classified waters of the State occurs or can be reasonably predicted to occur considering hydrogeological conditions, modeling, or any other available evidence.~~

~~(2) An imminent hazard or threat to the environment, public health, or safety exists.~~

~~(3) A violation of any standard in groundwater occurring in the bedrock, including limestone aquifers in Coastal Plain sediments, unless it can be demonstrated that the violation will not adversely affect, or have the potential to adversely affect, a water supply well.~~

(k) ~~Where operation of a disposal system permitted under this section results in exceedances of the groundwater quality standards at or beyond the compliance boundary established under subsection (i) of this section, exceedances shall be remedied through cleanup, recovery, containment, or other response as directed by the Commission.~~ boundary, the Commission shall require the permittee to undertake corrective action, without regard to the date that the system was first permitted, to restore the groundwater quality by assessing the cause, significance, and extent of the violation of standards and submit the results of the investigation and a plan and proposed schedule for corrective action to the Director or the Director's designee. The permittee shall implement the plan as approved by, and in accordance with, a schedule established by the Director or the Director's designee. In establishing a schedule the Director or the Director's designee shall consider any reasonable schedule proposed by the permittee.

**SECTION 12.(b)** Section 46(b) of S.L. 2013-413 is repealed.

**SECTION 12.(c)** The Environmental Management Commission shall review the compliance boundary and corrective action provisions of Subchapter 2L of Title 15A of the North Carolina Administrative Code for clarity and internal consistency. The Commission shall report the results of its review, including any recommendations, to the Environmental Review Commission no later than December 1, 2014.

**From Session Law 2015-1: SECTION 3.5.** G.S. 143-215.1(k) reads as rewritten:

"(k) Where operation of a disposal system permitted under this section results in exceedances of the groundwater quality standards at or beyond the compliance boundary, the Commission shall require the permittee to undertake corrective action, without regard to the date that the system was first permitted, to restore the groundwater quality by assessing the cause, significance, and extent of the violation of standards and submit the results of the investigation and a plan and proposed schedule for corrective action to the ~~Director or the Director's designee, Secretary.~~ Secretary. The permittee shall implement the plan as approved by, and in accordance with, a schedule established by the ~~Director or the Director's designee, Secretary.~~ Secretary. In establishing a schedule the ~~Director or the Director's designee~~ Secretary shall consider any reasonable schedule proposed by the permittee."

**SESSION LAW 2015-104 (Senate Bill 7, signed into law June 24, 2015)**

AN ACT TO ALLOW FOOD STANDS TO PROVIDE TABLES AND CHAIRS FOR CUSTOMERS TO USE WHILE CONSUMING DRINKS OR FOOD UPON THE PREMISES AND TO AUTHORIZE PUSHCARTS OR MOBILE FOOD UNITS TO PREPARE AND SERVE FOOD ON THE PREMISES, PROVIDED THEY ARE BASED FROM A COMMISSARY OR RESTAURANT LOCATED ON THE PREMISES OF A FACILITY CONTAINING THREE THOUSAND PERMANENT SEATS.

The General Assembly of North Carolina enacts:

**SECTION 1.** G.S. 130A-248 is amended by adding a new subsection to read: "(a6) Notwithstanding any provision of this Part or any rules adopted pursuant to G.S. 130A-335(e), a permitted food stand may elect to provide tables and not more than eight seats for customers to use while eating or drinking on the premises. Addition of seats under this subsection shall not require further evaluation of the adequacy of the approved sanitary sewage system."

**SECTION 2.** G.S. 130A-248(c1) reads as rewritten:

"(c1) The Commission shall adopt rules governing the sanitation of pushcarts and mobile food units. A permitted restaurant or commissary shall serve as a base of operations for a pushcart. A mobile food unit shall meet all of the sanitation requirements of a permitted commissary or shall have a permitted restaurant or commissary that serves as its base of operation. Pushcarts or mobile food units that are based from a permitted commissary or restaurant that is located on the premises of a facility which contains at least 3,000 permanent seats shall be allowed to prepare and serve food on the premises. Raw meat, poultry, and fish shall be prepared in a permitted commissary or restaurant in a pre-portioned or ready-to-cook form. Pushcarts or mobile food units that handle raw ingredients shall be equipped with a handwashing sink. All open food and utensils shall be provided with overhead protection or otherwise equipped with individual covers, such as domes, chafing lids, or cookers with hinged lids. Food equipment and supplies shall be located in enclosed areas and protected from environmental contamination when not in operation."

**SECTION 3.** Section 1 of this act becomes effective October 1, 2015, the remainder of the act is effective when it becomes law.

**SESSION LAW 2015-147 (House Bill 705, signed into law July 13, 2015)**

AN ACT TO (1) BROADEN THE TYPES OF SUBSURFACE WASTEWATER TREATMENT SYSTEMS THAT MAY SERVE AS THE BASIS FOR DESIGNATED REPAIR AREA REQUIREMENTS FOR REPLACEMENT WASTEWATER TREATMENT SYSTEMS AND (2) MAKE CAPACITY AND MANAGEMENT CHANGES FOR CERTAIN DISPERSAL SYSTEMS.

The General Assembly of North Carolina enacts:

**SECTION 1.(a) Definitions.** – "Repair Reserve Rule" means 15A NCAC 18A .1945 (Available Space) for purposes of this section and its implementation.

**SECTION 1.(b) Repair Reserve Rule.** – Until the effective date of the revised permanent rule that the Commission for Public Health is required to adopt pursuant to Section 1(d) of this act, the Commission and the Department of Health and Human Services shall implement the Repair Reserve Rule, as provided in Section 1(c) of this act.

**SECTION 1.(c) Implementation.** – Notwithstanding the Repair Reserve Rule, the Commission shall allow a repair area that accommodates replacement systems described under 15A NCAC 18A .1955 (Design Installation Criteria for Conventional Sewage Systems), 15A NCAC 18A .1956 (Modifications to Septic Tank Systems), 15A NCAC 18A .1957 (Criteria for Design of Alternative Sewage Systems), and innovative or accepted systems approved under 15A NCAC 18A .1969 (Approval and Permitting of On-Site Subsurface Wastewater Systems, Technologies, Components, or Devices), provided that the designated repair area otherwise meets the requirements for those types of replacement systems. Nothing in this act is intended to repeal or amend existing portions of the Repair Reserve Rule granting exemptions from repair area requirements.

**SECTION 1.(d) Additional Rule-Making Authority.** – The Commission shall adopt a rule to amend the Repair Reserve Rule consistent with Section 1(c) of this act. Notwithstanding G.S. 150B-19(4), the rule adopted by the Commission pursuant to this section shall be substantively identical to the provisions of Section 1(c) of this act. Rules adopted pursuant to this section are not subject to Part 3 of Article 2A of Chapter 150B of the General Statutes. Rules adopted pursuant to this section shall become effective as provided in G.S. 150B-21.3(b1) as though 10 or more written objections had been received as provided by G.S. 150B-21.3(b2).

**SECTION 1.(e) Sunset.** – Section 1(c) of this act expires when permanent rules adopted as required by Section 1(d) of this act become effective.

**SECTION 2.(a) Definitions.** – "Sand Lined Trench System Rule" means 15A NCAC 18A .1956(7)(d) (Modifications to Septic Tank Systems: Sand Line Trench System) for purposes of this section and its implementation.

**SECTION 2.(b) Sand Lined Trench System Rule.** – Until the effective date of the revised permanent rules that the Commission for Public Health is required to adopt pursuant to Section 2(d) of this act, the Commission and the Department of Health and Human Services shall implement the Sand Lined Trench System Rule, as provided in Section 2(c) of this act.

**SECTION 2.(c) Implementation.** – Notwithstanding the Sand Lined Trench System Rule, a Public Management Entity with a Certified Operator, if required by Article 3 of Chapter 90A of the General Statutes, shall not be required for sand lined trench systems when drainage is utilized to lower the water table on a site.

**SECTION 2.(d) Additional Rule-Making Authority.** – The Commission shall adopt a rule to amend the Sand Lined Trench System Rule consistent with Section 2(c) of this act. Notwithstanding G.S. 150B-19(4), the rule adopted by the Commission pursuant to this section shall be substantively identical to the provisions of Section 2(c) of this act. Rules adopted pursuant to this section are not subject to Part 3 of Article 2A of Chapter 150B of the General Statutes. Rules adopted pursuant to this section shall become effective as provided in G.S. 150B-21.3(b1) as though 10 or more written objections had been received as provided by G.S. 150B-21.3(b2).

**SECTION 2.(e) Sunset.** – Section 2(c) of this act expires when permanent rules adopted as required by Section 2(d) of this act become effective.

**SECTION 3.** The Department of Health and Human Services or the Commission for Public Health, as appropriate, shall repeal 15A NCAC 18A .1956(6)(c) (Modifications to Septic Tank Systems Rule: Sapolite System, Design Daily Flow) on or before December 1, 2015. Until the effective date of the repeal of the rule required pursuant to this section, the Secretary of Health and Human Services, the Department of Health and Human Services, the Commission for Public Health, local health departments, or any other political subdivision of the State shall not implement or enforce 15A NCAC 18A .1956(6)(c) (Modifications to Septic Tank Systems Rule: Sapolite System, Design Daily Flow).

**SECTION 4.** This act is effective when it becomes law.

**SESSION LAW 2015-286 (House Bill 765, signed into law October 22, 2015)**

AN ACT TO PROVIDE FURTHER REGULATORY RELIEF TO THE CITIZENS OF NORTH CAROLINA BY PROVIDING FOR VARIOUS ADMINISTRATIVE REFORMS, BY ELIMINATING CERTAIN UNNECESSARY OR OUTDATED STATUTES AND REGULATIONS AND MODERNIZING OR SIMPLIFYING CUMBERSOME OR OUTDATED REGULATIONS, AND BY MAKING VARIOUS OTHER STATUTORY CHANGES.

The General Assembly of North Carolina enacts:

**PART IV. ENVIRONMENTAL AND NATURAL RESOURCES REGULATION  
ON-SITE WASTEWATER AMENDMENTS AND CLARIFICATIONS**

*Note: Sections that resulted in Changes to Article 11 of Chapter 130A and Article 5 of Chapter 90A are already incorporated into the published statutes shown above, and not repeated herein*

**SECTION 4.14.(a)** See Article 11, G.S. 130A-334

**SECTION 4.14.(b)** See Article 11, G.S. 130A-335

**SECTION 4.14.(c)** See Article 11, G.S. 130A-336.1

**SECTION 4.14.(d)** See Article 11, G.S. 130A-338

**SECTION 4.14.(e)** See Article 11, G.S. 130A-339

**SECTION 4.14.(f)** The Commission for Public Health, in consultation with the Department of Health and Human Services, local health departments, and stakeholders representing the wastewater system industry, shall study the minimum on-site wastewater system inspection frequency established pursuant to Table V(a) in 15A NCAC 18A .1961 to evaluate the feasibility and desirability of eliminating duplicative inspections of on-site wastewater systems. In the conduct of its study, the Commission shall consider (i) the compliance history of wastewater systems, including whether operators' reports and laboratory reports are in compliance with Article 11 of Chapter 130A of the General Statutes and the rules adopted pursuant to that Article; (ii) alternative inspection frequencies, including the use of remote Web-based monitoring for alarm and compliance notification; (iii) whether the required verification visit conducted by local health departments shows a statistically significant justification for duplicative costs to the owner of the wastewater system; (iv) methods for notifications of changes to and expirations of operations contracts; and (v) methods for local health departments to provide certified operator management for sites that are not under contract with a water pollution control system operator certified pursuant to Part 1 of Article 3 of Chapter 90A of the General Statutes. The Commission shall report its findings and recommendations, including any legislative proposals, to the Environmental Review Commission and the Joint Legislative Oversight Committee on Health and Human Services on or before March 1, 2016.

**SECTION 4.14.(g)** See Article 11, G.S. 130A-336

**SECTION 4.14.(h)** The Commission for Public Health, in consultation with the Department of Health and Human Services, local health departments, stakeholders who represent the wastewater system industry, and other interested parties shall study the period of validity for improvement permits and authorizations for wastewater system construction and evaluate the costs and benefits of a range of periods of validity. In the conduct of this study, the Commission shall also evaluate the feasibility and desirability of conducting an abbreviated review and possible extension of a permit or authorization that is due to expire at a lower cost to the applicant. The Commission shall report its findings and recommendations, including any legislative proposals, to the Environmental Review Commission and the Joint Legislative Oversight Committee on Health and Human Services on or before April 1, 2016.

**SECTION 4.14.(i)** Any improvement permit or authorization for wastewater system construction that is in effect on the effective date of this act which is scheduled to expire on or before July 1, 2016, shall remain in effect until July 1, 2016.

**SECTION 4.14.(j)** See Article 11, G.S. 130A-342

**SECTION 4.14.(k)** This section is effective when this act becomes law. The Commission for Public Health shall adopt temporary rules pursuant to Sections 4.14(a) through 4.14(e), Section 4.14(g), and Section 4.14(j) of this act no later than June 1, 2016, and shall adopt permanent rules pursuant to Sections 4.14(a) through 4.14(e), Section 4.14(g), and Section 4.14(j) of this act no later than January 1, 2017. No person shall utilize the engineered permit option authorized pursuant to G.S. 130A-336.1, as enacted by Section 4.14(c) of this act, however, until such time as the rules adopted by the Commission pursuant to Section 4.14(c) of this act become effective.

**CLARIFY CERTIFICATION REQUIREMENTS FOR PLUMBING CONTRACTORS WHO INSTALL OR REPAIR GREASE TRAPS**

**SECTION 4.14A.** See G.S. 90A-72

**AMEND APPROVAL OF ON-SITE WASTEWATER SYSTEMS**

**SECTION 4.15.(a)** See G.S. 130A-343

**SECTION 4.15.(b)** The Commission for Public Health shall review and amend its rules to implement Section 4.15(a) of this act.

**SECTION 4.15.(c)** Beginning January 1, 2016, and every quarter thereafter until all rules required pursuant to Sections 4.14 and 4.15 of this act are adopted or amended, the Commission for Public Health shall submit written reports as to its progress on adopting or amending rules as required by Sections 4.14 and 4.15 of this act to the Environmental Review Commission and the Joint Legislative Oversight Committee on Health and Human Services. The Commission shall supplement the written reports required by this subsection with additional written and oral reports as may be requested by the Environmental Review Commission and the Joint Legislative Oversight Committee on Health and Human Services. The Commission shall submit the written reports required by this subsection whether or not the General Assembly is in session at the time the report is due.

**SECTION 4.15.(d)** The Commission for Public Health, in consultation with the Department of Health and Human Services, local health departments, and stakeholders representing the wastewater system industry, shall study the costs and benefits of requiring treatment standards greater than those listed by nationally recognized standards, including the recorded advantage of such higher treatment standards for the protection of the public health and the environment. The Commission shall report its findings and recommendations, including any legislative proposals, to the Environmental Review Commission and the Joint Legislative Oversight Committee on Health and Human Services on or before March 1, 2016.

**SESSION LAW 2015-207 (House Bill 538)**

AN ACT TO AMEND AND CLARIFY THE POWERS OF WATER AND SEWER AUTHORITIES, TO AUTHORIZE COUNTIES AND CITIES TO PLEDGE A SECURITY INTEREST IN AN ESCROW ACCOUNT UNDER CERTAIN CONDITIONS, TO ALLOW THE LOCAL GOVERNMENT COMMISSION TO AUTHORIZE A THIRTY-YEAR MATURITY DATE FOR THE FINANCING OF CERTAIN WATER SYSTEM PROJECTS, TO AUTHORIZE METROPOLITAN WATER DISTRICTS AND METROPOLITAN WATER AND SEWERAGE DISTRICTS TO ENTER INTO INSTALLMENT CONTRACT FINANCING AGREEMENTS, AND TO REQUIRE PUBLIC OR COMMUNITY WASTEWATER SYSTEMS TO ACCEPT LIQUID CONDENSATE GENERATED BY RESIDENTIAL HEATING AND COOLING SYSTEMS.

The General Assembly of North Carolina enacts:

**SECTION 6.** Article 11 of Chapter 130A of the General Statutes is amended by adding a new section to read: "**§ 130A-345. Disposal of liquid condensate from residential heating and cooling systems.** Notwithstanding any other provision of law, every public or community wastewater system, as defined in G.S. 130A-334(8), shall provide for the collection of liquid condensate from residential heating and cooling systems by the public or community wastewater system."

**SECTION 7.** This act is effective when it becomes law.