

NORTH CAROLINA DEPARTMENT OF ENVIRONMENT, HEALTH AND
NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PIPE PENETRATION SEAL CONDITIONAL APPROVAL

Septic Tank PIPE PENETRATION SEAL CONDITIONAL Approval: PS-10

ISSUED TO: Mr. Mathew A. Tomkinson
North American Seals Manager
Press-Seal Gasket Corporation
P.O. Box 10482
Fort Wayne, IN 46852
Phone: 800-348-7325, Fax: (219) 436-1908, pressseal@press-seal.com

FOR: Pipe penetration seal Model "Cast-A-Seal".

DATE: December 18, 1998

In accordance with North Carolina General Statute 130A-335, 130A-335.1, and 15A NCAC 18A .1954, an application by Matthew A. Tomkinson of PRESS-SEAL GASKET CORPORATION for approval of septic tank pipe penetration seals has been reviewed. This penetration seal "CAST-A-SEAL" has been found to meet the requirements established by statute and rule when properly incorporated into the design of premanufactured septic tanks, when the following conditions for use, installation, operation and maintenance are met:

I. Description:

"CAST-A-SEAL" shall be designed and manufactured in accordance with plans, specifications and supporting documents provided by the manufacturer in their application for approval submitted to the On-Site Wastewater Section. The On-Site Wastewater Section shall be notified in writing of any new or modifications to the approved seals prior to use in septic tank systems.

II. Use:

A septic tank manufacturer may propose to use one or more of these one or more of their septic tanks. "Cast-A-Seal" is designed to fit a four-inch pipe. The septic tank manufacturer must notify the On-Site Wastewater Section in accordance with Rule .1953 of the tanks in which they propose to utilize any of these conditionally approved seals showing any modifications to the approved tank plans which may be necessary to utilize the proposed risers seals.

III. Installation:

The seals must be cast in place for concrete septic tanks. For septic tanks made with other material such as Plastics a specific installation procedure

and detail must be proposed by the Septic Tank Manufacturer.

IV. Maintaining conditional approval status:

The approval status is governed by Rule .1954(e). The approval status shall also be revised as part of the permanent rule making process for rules 15A NCAC 18A .1952 through .1954.

Approved by: signed by Ishwar C. Devkota
1998

Date: December 18,